

Reference

NBS
Publi-
cations

NAT'L INST. OF STAND & TECH R.I.C.



A11105 618735

NBSIR 81-2378

A11101 776840

Heat Transfer Analysis of Underground Heat and Chilled-Water Distribution Systems

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
National Engineering Laboratory
Center for Building Technology
Washington, DC 20234

November 1981

Prepared for
Naval Facilities Engineering Council
U.S. Navy
Washington, DC 20390

Directorate of Civil Engineering
U.S. Air Force
Washington, DC 20330

and

Office of Chief of Engineers
U.S. Army
Washington, DC 20304

QC

100

.U56

81-2378

1981

NBSIR 81-2378

NATIONAL BUREAU
OF STANDARDS
LIBRARY

DEC 7 1981

HEAT TRANSFER ANALYSIS OF UNDERGROUND HEAT AND CHILLED-WATER DISTRIBUTION SYSTEMS

T. Kusuda

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
National Engineering Laboratory
Center for Building Technology
Washington, DC 20234

November 1981

Prepared for
Naval Facilities Engineering Council
U.S. Navy
Washington, DC 20390

Directorate of Civil Engineering
U.S. Air Force
Washington, DC 20330

and

Office of Chief of Engineers
U.S. Army
Washington, DC 20304



U.S. DEPARTMENT OF COMMERCE, Malcolm Baldrige, *Secretary*
NATIONAL BUREAU OF STANDARDS, Ernest Ambler, *Director*

Heat Transfer Analysis of Underground Heat and Chilled-Water Distribution Systems

T. Kusuda

National Bureau of Standards

ABSTRACT

Simplified calculation procedures for determining heat exchange between the earth and a multiplicity of buried pipes having different temperature and thermal insulation are presented. The procedures deal with cases where pipes are buried side by side, as well as those when several pipes are bundled in a conduit. The effects of seasonal variation of earth temperature are treated in a quasi-steady-state equation that includes the soil thermal properties, depth of burial, pipe sizes, and relative locations of pipes. Sample calculations are included, together with the Fortran program listing and thermal properties of earth to be used for the calculations.

Key words: computer program; earth temperature; heat transfer; pipes; thermal insulation; thermal properties; underground systems.

TABLE OF CONTENTS

	<u>Page</u>
Abstract	iii
1. Introduction	1
2. Theoretical Background for Underground Pipe Heat Transfer	2
2.1 Single Shallow Pipe System	2
2.2 Multiple Pipe System	5
2.3 Pipes in an Underground Conduit	13
2.4 Underground Pipe in an Insulated Trench	18
3. Earth Temperature Data	20
4. Sample Problems and Solutions	22
5. Summary	25
6. References	25
7. Unit Conversion Factor	26
Appendix A. Earth Temperature Tables for Underground Heat-Distribution- System Design	A-1
Appendix B. Computer Program Listing for Multiple Pipe Heat Transfer and Economic Analysis	B-1

1. INTRODUCTION

Although underground heat distribution systems for a complex of buildings, such as college campuses and military bases, have been widely used in the United States for the past several decades, not much attention has been given to heat transfer analysis other than to such technical problems as the possibility of failure of the piping system from corrosion, thermal expansion difficulties, or moisture penetration through the thermal insulation. This is largely because many of the underground installations designed to distribute steam or hot water are purposely well insulated. Until recently, heat loss from these pipes has been considered small when compared with the total heat energy being transmitted through the pipe, providing that the thermal insulation is not damaged and rendered ineffective by leaking pipe fluid or from ground moisture. Thus, the main emphasis is placed on the preservation of a dry insulation around the pipe, corrosion protection of the conduit which houses the piping system, and the design of the piping system to minimize stress caused by the thermal expansion and contraction.

Since the early part of the 1960's when underground chilled water distribution systems began to gain popular acceptance for district cooling, the economic consideration as to whether the chilled water pipes should be insulated or not has required a careful reevaluation of the heat transfer problem [1].

Underground chilled water pipes are sometimes installed uninsulated, allowing a considerable savings in capital investment, especially for a large district cooling system. The uninsulated chilled water system appears justified on the following basis:

- a. Ground temperature is not severely affected by the presence of a deeply buried uninsulated chilled water pipe, and soil ecology and plant life are not unduly affected.
- b. Heat gain from the surrounding earth to large chilled-water pipes is usually a very small part of the total refrigeration load, and increases in the temperature of the chilled water being circulated in the underground piping network are not significant.
- c. There is no heat source such as an underground heat distribution system in the vicinity of the chilled water pipe.

Although item a is unquestionably valid, item b may be less so, particularly when the pipe diameter is small, long lengths of pipe are used, and when the earth surrounding the pipe remains warm and conductive for long periods of time. Item c is often invalid because in many instances underground chilled water lines run parallel and close to the steam and/or hot water lines.

The question is under what conditions is it necessary to insulate underground chilled-water pipes? If insulation becomes necessary, how much is needed? In order to answer this question, a comprehensive heat transfer calculation methodology is needed to analyze the situation whereby several underground pipes of different temperatures are buried side by side. This report presents a

recommended procedure and sample calculation to solve multiple pipe underground heat and chilled water distribution systems.

2. THEORETICAL BACKGROUND FOR UNDERGROUND PIPE HEAT TRANSFER

Except for the work of Loudon [2], very few papers have been published in the past treating the realistic conditions applicable to the analysis of underground pipe heat transfer. Most of the analytical solutions readily available for estimating heat transfer to and from underground pipes are either steady-state solutions for a pipe at shallow depths or transient heat conduction solutions for a single deep underground pipe. All of these solutions are based upon the assumption that the earth surrounding the pipe is homogeneous, the thermal properties of the earth are constant, and the temperature of the earth at reasonable distances from the pipe is constant and unaffected by the existence of the pipe.

It has been well known that these assumptions are unrealistic because thermal properties as well as earth temperatures change with respect to time and space due to seasonal change of the earth surface temperature and also due to movement of the soil moisture or ground water around the pipe. Analytical solutions which take into account these realistic situations are, however, extremely difficult to obtain and are not expected to be available in the near future. Therefore, the approach here was to examine quasi-steady-state heat transfer theories applicable to seasonal change of earth temperature. The method would provide approximate solutions for several practical problems, inclusive of multiple-pipe situations.

2.1 SINGLE SHALLOW PIPE SYSTEM (figure 1)

The solution for steady-state heat conduction from an underground pipe installed horizontally at a finite depth in homogenous soil of constant property can be found in several heat transfer texts [3,4]. This solution is based upon the potential flow theory and is obtained by the use of the "mirror-image" technique [3]. According to this technique, the heat loss Q from the unit length of the pipe of temperature T_p to the undisturbed ground at an average temperature T_G can be approximated by following equation:

$$Q = \frac{2\pi k_s (T_p - T_G)}{\ln \left(\frac{d}{r} + \sqrt{\left(\frac{d}{r}\right)^2 - 1} \right)}, \quad (1)$$

where k_s = average thermal conductivity of earth surrounding the pipe (see figure 2)

d = depth of the pipe measured from the ground surface to the center-line of the pipe

r = external radius of the pipe where the pipe temperature is T_p

$\ln$ = natural logarithm

Another form of the above equation usually cited is




Figure 1. Single-pipe system (Nomenclature).




Figure 2. Thermal conductivity versus moisture content for soils.

$$Q = \frac{2\pi k_S (T_P - T_G)}{\ln \left(\frac{2d}{r} \right)} \quad (2)$$

which is a further approximate representation of equation (1) when $d/r \gg 1$, or when the radius of the pipe is sufficiently smaller than the depth.

Equations (1) and (2) were developed for the average pipe surface temperature T_P and the average temperature T_G of the undisturbed earth at some distance from the pipe inclusive of the ground surface.

When the pipe is insulated, a term for the thermal resistance of the insulation layer must be added to the above equations. If the pipe is uninsulated and the pipe material has high thermal resistance, such as non-metallic pipes, the thermal resistance term for the pipe wall should also be included in the pipe heat transfer equation in such a way that

$$Q = K_P (T_F - T_G) \quad (3)$$

$$\frac{1}{K_P} = \frac{1}{2\pi k_S} \left\{ \frac{k_S}{r_W h_W} + \frac{k_S}{k_W} \ln \left(\frac{r-t}{r_W} \right) + \frac{k_S}{k_I} \ln \left(\frac{r}{r-t} \right) + \ln \left(\frac{d}{r} + \sqrt{\left(\frac{d}{r} \right)^2 - 1} \right) \right\} ,$$

in consistent units where


K_P = pipe heat transfer factor
 T_F = pipe fluid temperature
 T_G = undisturbed average earth temperature surrounding the pipe
 r_W = inside radius of the pipe
 r = external radius of the insulation
 t = thickness of the pipe insulation
 h_W = heat transfer coefficient of the pipe fluid
 k_S = thermal conductivity of the earth surrounding the pipe
 k_W = thermal conductivity of the pipe wall
 k_I = thermal conductivity of the pipe insulation .

The above expression is, however, only approximately correct since actual heat flow is not radial and may result in error if $k_S/k_I \gg 1$. The extent of the error due to this approximation, is however, unknown.

Moreover, for the calculation of pipe heat transfer factor for metallic pipe K_P , it is customary to ignore the terms involving h_W and k_W because of their very small numerical value. Even for the non-metallic pipes, the term involving h_W is usually neglected unless the pipe fluid velocity is extremely small.

2.2 MULTIPLE PIPE SYSTEM: (figure 3)

The foregoing discussion is for a single isolated underground pipe. In practice, several pipes may be installed in the same vicinity. Thus, heat



UNDISTURBED AVERAGE EARTH TEMPERATURE, T_G
 UNDISTURBED AVERAGE THERMAL CONDUCTIVITY, k_s

Figure 3. Multiple-pipe system (bare pipes).

transfer around each pipe is affected by the presence of its neighbor. The steady-state heat transfer for a multiple-pipe system was explored in detail during this study and is presented in this report because little information was available from reference material. The multiple-pipe system considered in this section is shown schematically in figures 3 and 4. The undisturbed earth temperature is designated by T_G , whereas the earth temperature at any point $(x, -y)$ in the region of pipe heat transfer is designated by T .

The difference in temperature $T - T_G$, due to M number of heat sources (or sinks) can be obtained by the superposition of mirror image technique employed for the single pipe problem (such as found in reference 3) in consistent units as follows:

$$T - T_G = \sum_{i=1}^m \frac{Q_i}{4\pi k_S} \ln \left\{ \frac{(x-a_i)^2 + (y-d_i)^2}{(x-a_i)^2 + (y+d_i)^2} \right\}, \quad (4)$$

where Q_i = strength of the i -th heat source (if plus) or sink (if minus). It is the total heat loss (if plus) or heat gain (if minus) of the i -th pipe per unit length.

k_S = thermal conductivity of earth surrounding all the pipes.

a_i and d_i = coordinates of the center of the i -th pipe referring to an arbitrary origin of the coordinate system $(x, -y)$. If, for instance, the coordinates were so chosen that $x_1 = 0$ and $y_1 = -d_1$, the origin of the coordinates for the multiple pipe system would be at the ground surface above the centerline of the first pipe.

By denoting the exterior radius of the k -th pipe as r_k , the pipe surface can be expressed as

$$(x-a_k)^2 + (y+d_k)^2 = r_k^2. \quad (5)$$

Or with the use of the polar coordinate system

$$x = a_k + r_k \sin \theta \quad (6)$$

$$y = r_k \cos \theta - d_k$$

where θ is the angular position of a point on the surface around the k -th pipe as shown in figure 3. Equations (5)/(6) represent a point on a circle of radius r_k , the center of which is the line heat source of strength Q_k Btu/hr.ft. The temperature of the point defined by $(x, -y)$, however, would be influenced by all the other m lines heat sources such as Q_i ($i=1, 2, \dots, m$) and would vary from point to point over the circle as a function of θ . By substituting (6) into (4), the surface temperature distribution for the k -th pipe can be obtained as a function of θ as follows:

$$T_k(\theta) - T_G = \sum_{i=1}^m \frac{Q_i}{4\pi k_S} \ln \left\{ \frac{(a_k - a_i + r_k \sin \theta)^2 + (r_k \cos \theta - d_k - d_i)^2}{(a_k - a_i + r_k \sin \theta)^2 + (r_k \cos \theta - d_k + d_i)^2} \right\}. \quad (7)$$

By denoting further that

$$A_{ki}^2 = \frac{(a_k - a_i)^2 + (d_k - d_i)^2}{r_k^2}$$

$$A_{ki}'^2 = \frac{(a_k - a_i)^2 + (d_k + d_i)^2}{r_k^2}$$

$$\tan \zeta_{ik} = \frac{a_k - a_i}{d_k - d_i}$$

$$\tan \zeta_{ik}' = \frac{a_k - a_i}{d_k + d_i}$$
(8)

equation (7) becomes

$$T_k(\theta) - T_G = \sum_{\substack{i=1 \\ i \neq k}}^m \frac{Q_i}{4\pi k_S} \ln \left\{ \frac{A_{ik}'^2 - 2A_{ik}' \cos(\theta + \zeta_{ik}') + 1}{A_{ik}^2 - 2A_{ik} \cos(\theta + \zeta_{ik}) + 1} \right\}$$

$$+ \frac{Q_k}{4\pi k_S} \ln \left\{ 1 - 4 \frac{d_k}{r_k} \cos \theta + \left(\frac{2d_k}{r_k} \right)^2 \right\}$$
(9)

With the assumption also that the circle represented by equations (5)/(6) is the cross section of a pipe which is losing heat Q Btu/hr.ft at average surface temperature T_k , one can approximate the value of T_k by integrating with respect to θ as follows:

$$T_k - T_G = \frac{1}{2\pi} \int_0^{2\pi} (T_k(\theta) - T_G) d\theta$$

$$= \frac{1}{4\pi k_S} \sum_{i=1}^M Q_i \ln \left(\frac{A_{ik}'^2}{A_{ik}^2} \right) + \frac{Q_k}{4\pi k_S} \ln \left(\frac{2d_k}{r_k} \right)^2$$
(10)

Although this equation is consistent with the approximate solution for the case of the single-pipe heat transfer (equation 2) if $M = 1$, it is not recommended for the shallow large pipe problems where $d_k/r_k \approx 1$.

By defining matrix elements $P_{i,k}$ in such a manner that

$$P_{ik} = \ln \left(\frac{A_{ik}'^2}{A_{ik}^2} \right)$$
(11)

$$P_{kk} = \ln \left(\frac{2d_k}{r_k} \right)^2$$

the values of $Q_1, Q_2 \dots Q_M$ can now be obtained as a solution of the following simultaneous equations

$$\frac{1}{4\pi k_S} \begin{pmatrix} P_{11} & P_{12} & \dots & P_{1M} \\ P_{21} & P_{22} & \dots & P_{2M} \\ \cdot & & & \cdot \\ \cdot & & & \cdot \\ \cdot & & & \cdot \\ P_{M1} & P_{M2} & \dots & P_{MM} \end{pmatrix} \cdot \begin{pmatrix} Q_1 \\ Q_2 \\ \cdot \\ \cdot \\ \cdot \\ Q_M \end{pmatrix} = \begin{pmatrix} T_1 - T_G \\ T_2 - T_G \\ \cdot \\ \cdot \\ \cdot \\ T_M - T_G \end{pmatrix} \quad (12)$$

provided that the values of $T_1, T_2 \dots T_M$ are known.

The above equations are for bare steel pipe systems where the average exterior pipe surface temperature may safely be approximated as equal to the pipe fluid temperature.

When the system includes non-metallic pipes or insulated pipes, the external surface temperatures (pipe-earth interface temperatures) $T_1, T_2 \dots T_M$ must be calculated first. Assuming, for the time being, that the values of $T_1, T_2 \dots T_M$ are known as well as the pipe fluid temperatures, $T_{F1}, T_{F2} \dots T_{FM}$, the heat transfer from the pipes $Q_1, Q_2 \dots Q_M$ may then be calculated by

$$Q_k = C_k(T_{Fk} - T_k) \quad \text{for } k=1, 2, \dots, M \quad (13)$$

where C_k = is the heat transfer coefficient for the k-th pipe for use with the thermal resistance between the pipe fluid and the external radius of the pipe or the pipe insulation where it interfaces with soil. The value of C_k may be approximated by

$$\frac{1}{C_k} = \frac{1}{2\pi} \frac{1}{k_{Ik}} \ln \left(\frac{r_k}{r_{Ik}} \right) + \frac{1}{k_{Mk}} \ln \left(\frac{r_{Ik}}{r_{Mk}} \right) + \frac{1}{r_{Mk} h_W} \quad (14)$$

In equation (14), k_I and k and k_{mDk} are the thermal conductivities of insulation and wall for the k-th pipe, whereas r_{Ik} and r_{Mk} are the external radii of the insulation and the wall, respectively.

The symbol h_W refers to the heat transfer coefficient between the pipe fluid and the pipe wall. The value of h_W is usually very high unless the pipe fluid velocity is extremely small, and consequently the last term of equation (14) is usually neglected.

By substituting equation (13) into (12) and rearranging the terms with respect to the pipe average surface temperature $T_1, T_2 \dots T_M$, the following simultaneous equations can be derived.

$$\begin{pmatrix} P'_{11} & P'_{12} & P'_{1M} \\ P'_{21} & P'_{22} & \dots & P'_{2M} \\ \cdot & & & \\ \cdot & & & \\ \cdot & & & \\ P'_{M1} & P'_{M2} & \dots & P'_{MM} \end{pmatrix} \cdot \begin{pmatrix} T_1 \\ T_2 \\ \cdot \\ \cdot \\ T_M \end{pmatrix} = \begin{pmatrix} B_1 \\ B_2 \\ \cdot \\ \cdot \\ B_M \end{pmatrix} \quad (15)$$

where

$$P'_{ik} = \frac{C_k P_{ik}}{4\pi k_S}$$


$$P'_{kk} = \frac{C_k P_{kk}}{4\pi k_S} + 1$$

$$B_i = T_G + \frac{1}{4\pi k_S} \sum_{k=1}^M C_k P_{ik} T_{Fk}$$

The solution of (15) yields a set of pipe-soil interface temperatures $T_1, T_2 \dots T_M$, thus permitting the calculation of pipe heat transfer by equation (13).

When equation (15) is to be solved for the multiple pipe system where some of the pipes are non-insulated steel pipes, fictitious insulation of arbitrary thickness with thermal conductivity identical to the surrounding soil may be assumed for the bare pipes. This procedure is necessary because the values of $P'_{i,k}$ and B_i are meaningless otherwise.

Computer programs have been developed during the course of this study to implement this derivation for the multiple pipe system. The Fortran listing of this program is included in Appendix B, which includes the life-cycle cost analysis of pipe insulation. A sample case selected is illustrated in figures 4 and 5 with the results of the calculations given in figure 5 to show relative effect between heat transfer and distance between pipes. The values in parentheses indicate percentage change from case 5, where each pipe is considered to be a single separate pipe system.



T_f = PIPE TEMPERATURE


T_g = EARTH TEMPERATURE, °F

k_s = THERMAL CONDUCTIVITY OF EARTH
BTU/HR, FT², °F/IN

k_I = THERMAL CONDUCTIVITY OF PIPE INSULATION
BTU/HR, FT², °F/IN

THREE-PIPE SYSTEM

Figure 4. Multiple-pipe system (insulated pipes).



CASE	a_1 in	a_2 in	Q_1 Btu/hr, ft	Q_2 Btu/hr, ft	Q_3 Btu/hr, ft
1	60	110	-17.89 (16)*	-20.30 (72)	81.24 (2)
2	55	100	-18.15 (12)	-21.46 (98)	81.57 (3)
3	55	90	-18.48 (14)	-22.82 (111)	82.00 (3)
4	45	80	-18.89 (16)	-24.46 (126)	82.55 (4)
5			-16.23 (0)	-10.82 (0)	79.40 (0)

* percentage change from the single-pipe system.

Figure 5. Sample calculation for multiple-pipe system (insulated pipe).

2.3 PIPES IN AN UNDERGROUND CONDUIT (figure 6)

When a group of pipes (some insulated and others non-insulated) are installed in the unvented underground conduit such as illustrated in figure 3, the following heat balance equation in consistent units would approximate the overall heat transfer process

$$\sum_{k=1}^m 2\pi r_k U_k (T_{Fk} - T_A) = K(T_A - T_G)$$

where M = total number of pipes in the conduit

r_k = outside radius of insulated or non-insulated pipes (k-th pipe)

U_k = overall heat transfer coefficient of the k-th pipe calculated by the following formula

$$\frac{1}{U_k} = \frac{r_k}{k_{Ik}} \ln \left(\frac{r_k}{r_k - t_k} \right) + \frac{1}{h_A} \quad (17)$$

k_{IDk} = thermal conductivity of the insulation around the k-th pipe

t_k = thickness of the insulation around the k-th pipe

h_A = outside surface heat transfer coefficient around the pipe (if no data are available)

T_{Fk} = temperature of the k-th pipe

T_A = air temperature in the conduit

T_G = undisturbed ground temperature surrounding the conduit

K = overall heat transfer factor of the conduit calculated by

$$\frac{1}{K} = \frac{1}{2\pi k_S} \frac{k_S}{(R-t)h_A} + \frac{k_S}{k_W} \ln \left(\frac{R}{R-t} \right) + \ln \left(\frac{d}{R} + \sqrt{\left(\frac{d}{R} \right)^2 - 1} \right) \quad (18)$$

k_S = thermal conductivity of earth surrounding the conduit

R = outside radius of the conduit*

k_W = effective thermal conductivity of the conduit wall

t = thickness of the conduit wall

d = depth of the conduit, distance between the ground surface and the center-line of the conduit

In equation (17), the value of heat transfer coefficient of air space h_A is not well known. For a concentric annular space, natural convection coefficient such as determined by formula developed by Grigull and Hauf [5] may be used in conjunction with standard radiation exchange formula. Figures 7 and 8 are obtained by such calculations.

In equations (17) and (18) the thermal resistance across the walls of the metallic pipe and metallic conduit were neglected from the formulas. If the metallic pipe or conduit is uninsulated, terms such as

* If the conduit is square in cross section instead of circular, equivalent radius may be approximated by $R = 0.56 W$, where W is the external width of the square conduit [2].




Figure 6. Pipes in a conduit.




Figure 7. Conduit air space heat transfer coefficient with respect to air space thickness.




Figure 8. Conduit air space heat transfer coefficient with respect to inner pipe diameters.

$$\frac{T_k}{k_{Ik}} \ln \left(\frac{r_k}{r_k - t_k} \right) \text{ or } \frac{k_S}{k_W} \ln \left(\frac{R}{R - t} \right)$$

may be dropped for the uninsulated non-metallic pipes or conduit; the wall thickness and its thermal conductivity value should be retained for the values for t_k and t , and k_{Ik} and k_W , respectively.

Solving for T_A from equation (16) and rearranging it, the heat transfer from k -th pipe in the conduit can be obtained as follows

$$Q_k = 2\pi r_k U_k (T_{Fk} - T_A) \quad , \quad (19)$$

where

$$T_A = \frac{KT_G + \sum_{k=1}^M 2\pi r_k U_k T_{Fk}}{K + \sum_{k=1}^M 2\pi r_k U_k} \quad . \quad (20)$$

If the conduit is ventilated and the ventilation mass flow rate is known to be G , lb/hr, equation (20) may be modified to yield

$$T_A = \frac{\sum_{k=1}^M 2\pi r_k U_k T_{Fk} + \frac{GC}{L} T_V + KT_G}{\sum_{k=1}^M 2\pi r_k U_k + \frac{GC}{L} + K} \quad (21)$$

where C_p = specific heat of air
 T_V = the ventilation air temperature
 L = total vented length of the conduit.

Data on ventilation rates for underground conduits are extremely scarce. Possible natural ventilation (without the wind effects) for a vented underground conduit system may be estimated as follows:

The theoretical natural draft ΔP_T , chimney effect, for an underground conduit of d ft depth may be calculated by [6]

$$\Delta P_T = 0.52 \cdot P_B \cdot d \left(\frac{1}{T_0} - \frac{1}{T_A} \right), \quad \text{inches of water} \quad (22)$$

where

P_B = atmospheric pressure, psi
 d = depth of the conduit, ft
 T_0 = absolute temperature of outdoor air, Rankine
 T_A = absolute temperature of conduit air, Rankine.

Also, the pressure drop ΔP_A of ventilation air flowing within an underground conduit can be calculated by

$$\Delta P_A = (C_i + C_o + \frac{fL}{D}) \cdot \left(\frac{V}{4005}\right)^2 \left(\frac{\rho}{0.075}\right) \text{ inches of water} \quad (23)$$

where C_i = entrance pressure loss coefficient

C_o = exit pressure loss coefficient

f = frictional pressure loss coefficient

L = length of the pipe between two consecutive vents along the pipe, ft

D = hydraulic diameter of the air passage within the conduit, ft

V = velocity of the air flow, ft/min

ρ = density of the air within the conduit, lb/ft³

By noting that the net ventilation flow G (lb/hr) can be expressed by

$$G = 60 \rho V A_C, \quad (24)$$

where A_C represents the cross sectional area for air passage within the conduit, and by noting the fact that ΔP_T and ΔP_A should be equal, it is possible to write

$$G = 240300 \rho A_C \sqrt{\frac{0.52 P_B d \left(\frac{1}{T_0} - \frac{1}{T_A}\right)}{(C_i + C_o) \frac{fL}{D} \left(\frac{\rho}{0.075}\right)}}. \quad (25)$$

For evaluation of G it is necessary to have data on C_i , C_o , and f . Moreover, equation (21) requires calculation of the value of T_A , conduit air temperature. Thus, the process of estimating the air temperature in a vented conduit requires iterative procedures which are cumbersome for manual calculation.

2.4 UNDERGROUND PIPE IN AN INSULATED TRENCH (figures 9 and 10)

In some installations, pipes are installed in a trench and an insulating material is poured over and around the pipes, as illustrated in figures 9 and 10. For the case of a single pipe system (fig. 9), a square region insulated in the trench may be treated as an equivalent annular ring of exterior radius $0.56 W$ (Loudon [2]), whereby W denotes the exterior width of the insulated region. The formulas and tables discussed in section 2.1 can then be used to approximate the pipe heat transfer. For the case shown in figure 10, or the multiple-pipe system, the computational method developed in section 2.2 can be used if the insulated region is assumed to consist of two equivalent annular zones such as shown by the dotted circles in figure 10. This assumption can be expected to yield erroneous results if the distance(s) between the pipes is (are) very small as compared with the total dimensions of the insulated zone. The precision can be improved, however, in the following manner. Repeat the above calculation on the premise that uninsulated pipes are buried in soil whose thermal properties are equal to those of the insulating material. The actual pipe heat transfer value should lie between the two sets of values thus calculated.




Figure 9. Pipe in an insulated trench.




Figure 10. Two pipes in an insulated trench.

3. EARTH TEMPERATURE DATA

When evaluating underground pipe heat transfer, it is essential that the temperature of the earth surrounding the pipe be known.

It has been customary when designing a heating pipe system to assume that the earth temperature is equal to the well water temperature for any given region, and that the well water temperature is close to the annual average air temperature. This concept appears reasonable as long as the annual average heat transfer from the heat distribution system is what is desired to be estimated. Moreover, well water temperature data, such as those compiled by Collins [7], are readily available for many localities in the United States. If, however, the maximum heat loss or heat gain of the underground pipes is desired, the well water temperature, which is the annual average earth temperature, is not adequate [8]. This is because the majority of the underground pipes are installed at a depth less than 10 ft from the surface, where the seasonal change of the ambient air temperature affects the heat transfer process.

Penrod's data [9] show, for instance, at a depth of 10 ft the temperature of the earth at Lexington, Kentucky is at its minimum in April, approximately 50 °F, and at its maximum in October, approximately 65 °F. Thus, it is considered to be impractical to evaluate the maximum heat gain to a chilled water pipe which was buried at a depth of 5 ft on the basis of the well water temperature, or on the annual average air temperature, which in this particular example is 58 °F.

According to reference [8], the annual earth temperature cycle, T , of a given thermal diffusivity, α , may be approximated by a simple harmonic function such as

$$T = A - Be^{-\sqrt{\frac{\pi}{\alpha P}} y} \cos \left(\frac{2\pi t}{P} - \phi - \sqrt{\frac{\pi}{\alpha P}} y \right) \quad (26)$$

where y = depth

P = period of the annual cycle, 365 days

t = time in days

A = annual average earth temperature ~ well water temperature

B = amplitude of the earth surface temperature cycle

ϕ = phase angles of the earth temperature cycle relative to a datum point

Reference [8] lists the values of A , B and ϕ for various earth temperature stations in the United States. While A and B depend on the monthly normal temperature cycle of a given climatic region, the value of ϕ is relatively constant at 0.6 radians.

The thermal diffusivity appearing in equation (26) is dependent upon the type of soil and its moisture content, as shown, for example, in figure 11.

The average earth temperature, T_G , as used in previous discussions can be evaluated by taking the integrated average of equation (26) to the depth of




Figure 11. Thermal diffusivity versus moisture content for several soils.

interest. The following equation yields an integrated value of T between $0 < y < 1$

$$T = A - B \cdot \gamma \cdot \cos \left(\frac{2\pi}{P} t - \phi - \psi \right) \quad (27)$$

$$\text{where } \gamma = \sqrt{\frac{x^2 - 2x \cos \beta + 1}{2\beta^2}}$$

$$\beta = \sqrt{\frac{\pi}{\alpha P}} \ell$$

$$x = e^{-\beta}$$

$$\psi = \tan^{-1} \left(\frac{1-x \cdot (\cos \beta + \sin \beta)}{1-x \cdot (\cos \beta - \sin \beta)} \right)$$

Since the center-line depth for most underground pipes is at around 10 ft, the integrated average temperatures for $\ell = 10$ ft were obtained for many places in the United States where the earth temperature records were maintained. The results of this integration calculation are presented in Appendix A for Winter (January 1), Spring (April 1), Summer (July 1) and Fall (October 1), representing the seasonal average values. Reference [8] shows that the majority of the thermal diffusivity values deduced from the measured earth temperatures in the United States are in the neighborhood of $0.025 \text{ ft}^2/\text{hr}$. Appendix A was, therefore, obtained for $\alpha = 0.025$.

4. SAMPLE PROBLEMS AND SOLUTIONS

This section presents some typical heat transfer problems and solutions to illustrate the use of the formulas and tables developed in section 2.

Evaluate the heat gain of a double pipe system (fig 12)--one pipe is for the supply of 42°F chilled water and another is for the return of 57°F water. These two pipes are bare steel pipes of 24-in diameter, and both are installed at the depth of 72 in from the ground surface to the center lines of the pipes and separated by a distance of 4 ft on center. Assume that the average undisturbed earth temperature around the pipe is 68°F and the thermal conductivity of the earth is $5 \text{ Btu} - \text{in/hr ft}^2^\circ\text{F}$.

Solution

Setting the origin of the coordinate system to be as shown in figure 3, the constants indicated in formulas (8) and (11) can be numerically evaluated as follows:

$$a_1 = 0, a_2 = 4$$

$$d_1 = d_2 = -6$$

$$r_1 = r_2 = 1$$

$$A_{12}^2 = 16, A'_{12}^2 = 160$$

$$P_{12} = P_{21} = \frac{1}{4\pi(\frac{5}{12})} \ln \left(\frac{160}{16} \right) = 0.440$$

$$P_{11} = P_{22} = \frac{1}{4\pi(\frac{5}{12})} \ln \left(\frac{12}{1} \right)^2 = 0.949$$

$$T_1 - T_G = 42 - 66 = -34$$

$$T_2 - T_G = 57 - 66 = -9$$

The pipe heat transfer Q_1 and Q_2 can then be solved from the following simultaneous equation (12)

$$0.949 Q_1 + 0.440 Q_2 = -34$$

$$0.440 Q_1 + 0.949 Q_2 = -9$$

The solutions to these equations are

$$Q_1 = -26.6 \text{ Btu/hr ft}$$


$$Q_2 = 2.84 \text{ Btu/hr ft.}$$

If these two pipes are separated at a distance so that each pipe is considered a single pipe sytem, Q_1 would have been -25.3 Btu/hr ft and $Q_2 = -9.48 \text{ Btu/hr ft}$. It is interesting to observe that the supply chilled-water pipe, 42°F , gains more heat by being in the vicinity of the return water pipe, 57°F , and the return water pipe actually loses heat instead of gaining it from the warmer earth.

The total system heat gain for the double pipe system is, however, 23.76 Btu/hr ft , much less than 34.76 Btu/hr ft had they been separated at a distance from each other.

Thus, there is a definite advantage by installing the chilled-water lines near each other. The advantage will be offset, however, if the two pipes are too close together, because then the supply water would be warmed up too much before it reaches its destination, by gaining heat from the return pipe.

Figure 12 also includes a table showing the effect of distance on heat transfer rates between the two pipes for values of 4 ft, 5 ft, 10 ft and infinity, and earth thermal conductivities of 10 and 5 $\text{Btu in/hr, ft}^2, ^\circ\text{F}$.



CASE	a	k_s	Q_1	Q_2
1	5'	10	- 50.79	0.565
2	∞	10	- 50.57	- 18.96
3	4'	10	- 53.21	5.687
4	4	5	- 26.60	2.843
5	∞	5	- 25.29	- 9.48
6	10	5	- 24.37	- 5.11

Figure 12. Sample double-pipe problem.

5. SUMMARY

Calculation methods were developed with sample problems as well as with computer program listings to approximate heat transfer of multiple pipe systems. Several pipes of different temperatures, insulations, and sizes installed in the same vicinity can be evaluated to study the heat transfer of each pipe affected by its neighboring pipes.

Seasonal average earth temperature data (from surface to approximately 10 ft depth) for underground piping distribution systems were developed for selected stations in the United States and for the thermal diffusivity of earth of $0.025 \text{ ft}^2/\text{hr}$. These data will permit the appraisal of the heat gain of chilled water systems as well as the heat loss of the hot water or steam pipes.

6. REFERENCES

- [1] Henderson, J. H., Economic Justification of Thermal Insulation of Underground Chilled Water Piping, American Society for Heating, Refrigerating and Air Conditioning Engineers (ASHRAE), Symposium Bulletin of Chilled Water Systems, January, 1970.
- [2] Loudon, A. G., Heat Loss from Underground Heating Mains, Journal of Institute for Heating and Ventilating Engineers (IHVE), London, November, 1957, pp. 196-203.
- [3] Eckert, E. R. G., Heat and Mass Transfer, McGraw-Hill Book Company, 1959, pp. 60-64.
- [4] McAdams, W. H., Heat Transmission, McGraw-Hill Book Company, 1954, page 25.
- [5] Grigull, U., and Hauf, Werner, National Convection in Horizontal Cylindrical Annuli, Proceedings of the Third International Heat Transfer Conference, American Institute of Chemical Engineers, 1966, pp 182-195.
- [6] Handbook of Fundamentals, American Society of Heating, Refrigerating and Air-Conditioning Engineers, 1967, page 406.
- [7] Collins, W. D., Temperature of Water Available for Industrial Use in the United States. U.S. Geological Survey, Water Supply Paper 520-F, 1925.
- [8] Kusuda, T., and Achenbach, P. R., Earth Temperature and Thermal Diffusivity at Selected Stations in the United States. ASHRAE Transactions, Vol. 1, Part 1, 1965, and more detailed data in NBS Report 8972 of the same title.
- [9] Penrod, E. B., Variation of Soil Temperature at Lexington, Kentucky from 1952-1956. University of Kentucky Engineering Experiment Station, Bulletin No. 57, September 1960.

7. UNIT CONVERSION FACTOR

English units are used throughout the text because of the fact that this report has been prepared for American practicing engineers and underground system manufacturers. The conversion multipliers to SI units for the pertinent variables are found as follows

			<u>Multiplier</u>
thermal conductivity	Btu-in/h·ft ² · F	to W/m·K	= 0.144
pipe heat transfer factor	Btu/h·ft·F	to W/m·K	= 1.728
heat transfer coefficient	Btu/h·ft ² · F	to W/m ² ·K	= 5.678
length	ft	to m	= 0.3048
velocity	ft/min	to m/s	= 0.00508
density	lb/min	to kg/m ³	= 16.03
pressure	in·H ₂ O	to Pa	= 249
pressure	psi	to KPa	= 6.89
temperature	°F	to °C	= (F-32)/1.8
	Rankine	to kelvin	= 0.556
thermal diffusivity	ft ² /h	to m ² /day	= 2.23

Table A

Illustrative Thermal Conductivities for Some Pipe Insulation Materials

Insulating Materials	Thermal Conductivity, k_I^* Btu/hr, ft ² , °F/in			
	<u>Temperature Level</u>			
	50 °F	100 °F	200 °F	300 °F
Cellular Glass	0.38	0.42	0.48	0.55
Cork Board	0.27	0.29		
Calcium Silicate	0.30	0.32	0.37	0.42
Expanded Polyurethane	0.16	0.18	0.21	
Expanded Polystyrene	0.25	0.26		
Mineral Fiber (rock, slag, or glass)	0.22	0.24	0.29	
Lightweight Concrete (perlite, vermiculite, etc., 30 psf)		0.9		
Sawdust		0.48		
Sand		2.1		

* Multiplier to obtain SI unit W/m•K is 0.144.



Appendix A. Earth Temperature Tables for Underground Heat-Distribution-System Design

The following list presents the average earth temperature in deg F from 0 to 10 feet below the surface for the four seasons of the year and for the whole year for the indicated locales. The temperatures were computed on the basis of the method described in the 1965 ASHRAE technical paper entitled "Earth Temperature and Thermal Diffusivity at Selected Stations in the United States" by T. Kusuda and P. R. Achenbach (in ASHRAE Transactions, Volume 71, Part I, p. 61, 1965) using the monthly average air temperatures published by the U.S. Weather Bureau for the listed localities in the United States. Earth temperatures are expressed in Fahrenheit degrees.

Location	Winter	Spring	Summer	Autumn	Annual
Alabama					
Anniston AP ^a	55.	58.	70.	67.	63.
Birmingham AP	54.	58.	71.	68.	63.
Mobile AP	61.	63.	74.	71.	67.
Mobile CO ^b	61.	64.	75.	72.	68.
Montgomery AP	58.	61.	73.	70.	65.
Montgomery CO	59.	62.	74.	71.	66.
Arizona					
Bisbee COOP ^c	55.	58.	70.	67.	62.
Flagstaff AP	35.	39.	54.	50.	45.
Ft Huachuca (proving ground)	55.	58.	71.	68.	63.
Phoenix AP	60.	64.	79.	75.	69.
Phoenix CO	61.	65.	80.	76.	70.
Prescott AP	46.	49.	65.	61.	55.
Tucson AP	59.	62.	76.	73.	68.
Winslow AP	45.	49.	65.	61.	55.
Yuma AP	65.	69.	84.	80.	75.
Arkansas					
Fort Smith AP	52.	56.	72.	68.	62.
Little Rock AP	53.	57.	72.	68.	62.
Texarkana AP	56.	60.	74.	71.	65.
California					
Bakersfield AP	56.	60.	74.	70.	65.
Beaumont CO	53.	56.	67.	64.	60.
Bishop AP	47.	51.	65.	61.	56.
Blue Canyon AP	43.	46.	58.	55.	50.
Burbank AP	58.	60.	68.	66.	63.

^a AP = Airport Data

^b CO = City Office Data

^c COOP = Cooperative Weather Station

Location	Winter	Spring	Summer	Fall	Annual
California					
Eureka CO	50.	51.	54.	54.	52.
Fresno AP	54.	58.		68.	63.
Los Angeles AP	58.	59.	64.	63.	61.
Los Angeles CO	60.	61.	68.	66.	64.
Mount Shasta CO	41.	44.	57.	54.	49.
Oakland AP	53.	54.	60.	59.	56.
Red Bluff AP	54.	58.	72.	69.	63.
Sacramento AP	53.	56.	67.	64.	60.
Sacramento CO	54.	57.	68.	65.	61.
Sandberg CO	47.	50.	63.	60.	55.
San Diego AP	59.	60.	66.	65.	62.
San Francisco AP	53.	54.	59.	57.	56.
San Francisco CO	55.	55.	59.	58.	57.
San Jose COOP	55.	57.	64.	62.	59.
Santa Catalina AP	57.	58.	64.	62.	60.
Santa Maria AP	54.	55.	60.	59.	57.
Colorado					
Alamosa AP	30.	35.	52.	48.	41.
Colorado Springs AP	39.	43.	59.	55.	49.
Denver AP	39.	43.	60.	56.	50.
Denver CO	41.	45.	61.	58.	51.
Grand Junction AP	39.	44.	65.	60.	52.
Pueblo AP	41.	45.	62.	58.	51.
Connecticut					
Bridgeport AP	40.	44.	61.	57.	50.
Hartford AP	39.	43.	61.	57.	50.
Hartford AP (Brainer)	39.	43.	60.	56.	50.
New Haven AP	40.	44.	60.	56.	50.
Delaware					
Wilmington AP	44.	48.	64.	60.	54.
Washington, D.C.					
Washington AP	47.	51.	66.	63.	56.
Washington CO	47.	51.	66.	63.	57.
Silver Hill OBS ^d	46.	50.	65.	61.	55.
Florida					
Apalachicola CO	63.	65.	75.	73.	69.
Daytona Beach AP	65.	67.	75.	74.	70.
Fort Myers AP	70.	71.	78.	76.	74.
Jacksonville AP	63.	66.	75.	73.	69.
Jacksonville CO	64.	66.	76.	73.	70.
Key West AP	74.	75.	80.	79.	77.
Key West CO	75.	76.	81.	79.	78.
Lakeland CO	68.	69.	77.	75.	72.

Location	Winter	Spring	Summer	Fall	Annual
Florida					
Melbourne AP	68.	70.	77.	75.	72.
Miami AP	72.	74.	79.	78.	76.
Miami CO	72.	73.	78.	77.	75.
Miami Beach COOP	74.	75.	80.	78.	77.
Orlando AP	68.	70.	77.	75.	72.
Pensacola CO	62.	64.	74.	72.	68.
Tallahassee AP	61.	64.	74.	72.	68.
Tampa AP	68.	69.	77.	75.	72.
West Palm Beach	71.	73.	79.	77.	75.
Georgia					
Albany AP	60.	63.	75.	72.	67.
Athens AP	54.	58.	71.	68.	63.
Atlanta AP	54.	57.	70.	67.	62.
Atlanta CO	54.	57.	70.	67.	62.
Augusta AP	56.	59.	72.	69.	64.
Columbus AP	56.	59.	72.	69.	64.
Macon AP	58.	61.	74.	71.	66.
Rome AP	53.	56.	70.	67.	61.
Savannah AP	60.	63.	74.	71.	67.
Thomasville CO	62.	64.	74.	72.	68.
Valdosta AP	61.	64.	74.	72.	68.
Idaho					
Boise AP	40.	44.	62.	58.	51.
Idaho Falls 46 W	30.	35.	55.	50.	42.
Idaho Falls 42 NW	28.	33.	54.	49.	41.
Lewiston AP	42.	46.	63.	59.	52.
Pocatello AP	35.	40.	59.	55.	47.
Salmon CO	32.	37.	56.	52.	44.
Illinois					
Cairo CO	49.	53.	70.	66.	60.
Chicago AP	38.	43.	62.	57.	50.
Joliet AP	37.	42.	61.	56.	49.
Moline AP	38.	43.	62.	58.	50.
Peoria AP	39.	44.	63.	58.	51.
Springfield AP	41.	45.	64.	60.	52.
Springfield CO	43.	47.	66.	62.	54.
Indiana					
Evansville AP	47.	51.	67.	63.	57.
Fort Wayne AP	39.	43.	61.	57.	50.
Indianapolis AP	41.	46.	64.	59.	52.
Indianapolis CO	43.	48.	65.	61.	54.
South Bend AP	38.	42.	61.	56.	49.
Terre Haute AP	42.	47.	65.	60.	53.

Location	Winter	Spring	Summer	Fall	Annual
Iowa					
Burlington AP	39.	44.	64.	59.	51.
Charles City CO	33.	38.	60.	55.	46.
Davenport CO	39.	44.	64.	59.	51.
Des Moines AP	37.	42.	63.	58.	50.
Des Moines CO	38.	43.	64.	59.	51.
Dubuque AP	34.	39.	60.	55.	47.
Sioux City AP	35.	40.	62.	57.	49.
Waterloo AP	35.	40.	61.	56.	48.
Kansas					
Concordia CO	42.	47.	67.	62.	54.
Dodge City AP	43.	48.	67.	62.	55.
Kansas					
Goodland AP	38.	43.	62.	57.	50.
Topeka AP	43.	47.	66.	62.	55.
Topeka CO	44.	49.	68.	63.	56.
Wichita AP	45.	50.	68.	64.	57.
Kentucky					
Bowling Green AP	47.	51.	67.	63.	57.
Lexington AP	44.	48.	65.	61.	54.
Louisville AP	46.	50.	67.	63.	56.
Louisville CO	47.	51.	67.	64.	57.
Louisiana					
Baton Rouge AP	61.	63.	74.	72.	67.
Burrwood CO	65.	67.	77.	74.	71.
Lake Charles AP	61.	64.	75.	73.	68.
New Orleans AP	63.	65.	75.	73.	69.
New Orleans CO	64.	66.	77.	74.	70.
Shreveport AP	58.	61.	75.	72.	66.
Maine					
Caribou AP	24.	29.	50.	45.	37.
Eastport CO	33.	37.	51.	48.	42.
Portland AP	33.	38.	56.	51.	44.
Maryland					
Baltimore AP	45.	49.	65.	61.	55.
Baltimore CO	47.	51.	67.	63.	57.
Frederick AP	44.	48.	65.	61.	55.
Massachusetts					
Boston AP	41.	44.	61.	57.	51.
Nantucket AP	41.	44.	57.	54.	49.
Pittsfield AP	34.	38.	55.	51.	44.
Worcester AP	36.	40.	58.	54.	47.

Location	Winter	Spring	Summer	Fall	Annual
Michigan					
Alpena CO	33.	37.	54.	50.	43.
Detroit Willow Run AP	38.	42.	60.	56.	49.
Detroit City AP	38.	43.	60.	56.	49.
Escanaba CO	30.	35.	53.	49.	42.
Michigan					
Flint AP	36.	40.	58.	54.	47.
Grand Rapids AP	36.	40.	58.	54.	47.
Grand Rapids CO	38.	42.	60.	56.	49.
East Lansing CO	36.	40.	58.	54.	47.
Marquette CO	31.	35.	53.	49.	42.
Muskegon AP	36.	40.	57.	53.	47.
Sault Ste Marie AP	28.	32.	51.	47.	39.
Minnesota					
Crookston COOP	25.	31.	55.	49.	40.
Duluth AP	25.	30.	52.	47.	38.
Duluth CO	26.	31.	52.	47.	39.
International Falls	22.	27.	51.	45.	36.
Minneapolis AP	32.	37.	60.	54.	46.
Rochester AP	31.	36.	58.	53.	44.
Saint Cloud AP	28.	33.	56.	51.	42.
Saint Paul AP	32.	37.	60.	54.	46.
Mississippi					
Jackson AP	57.	61.	73.	70.	65.
Meridian AP	57.	60.	72.	69.	64.
Vicksburg CO	58.	61.	74.	71.	66.
Missouri					
Columbia AP	43.	48.	66.	62.	55.
Kansas City AP	44.	49.	68.	64.	56.
Saint Joseph AP	42.	47.	67.	62.	54.
Saint Louis AP	45.	49.	67.	63.	56.
Saint Louis CO	46.	50.	68.	64.	57.
Springfield AP	45.	49.	66.	62.	56.
Montana					
Billings AP	35.	40.	59.	55.	47.
Butte AP	27.	31.	50.	45.	38.
Glasgow AP	27.	33.	56.	51.	42.
Glasgow CO	28.	34.	57.	52.	43.
Great Falls AP	34.	38.	56.	52.	45.
Havre CO	31.	36.	57.	52.	44.
Helena AP	31.	36.	55.	50.	43.
Helena CO	32.	36.	55.	50.	43.
Kalispell AP	32.	37.	54.	50.	43.
Miles City AP	32.	37.	59.	54.	45.

Location	Winter	Spring	Summer	Fall	Annual
Montana					
Missoula AP	33.	37.	56.	51.	44.
Nebraska					
Grand Island AP	38.	43.	64.	59.	51.
Lincoln AP	39.	44.	64.	60.	52.
Lincoln CO University	40.	45.	65.	61.	53.
Norfolk AP	35.	40.	62.	57.	48.
North Platte AP	37.	42.	62.	57.	49.
Omaha AP	39.	44.	65.	60.	52.
Scottsbluff AP	36.	41.	60.	56.	48.
Valentine CO	35.	40.	61.	56.	48.
Nevada					
Elko AP	34.	39.	57.	53.	46.
Ely AP	35.	39.	56.	52.	45.
Las Vegas AP	56.	60.	78.	74.	67.
Reno AP	40.	44.	58.	55.	49.
Tonopah	41.	45.	61.	57.	51.
Winnemucca AP	38.	42.	60.	56.	49.
New Hampshire					
Concord AP	33.	38.	56.	52.	45.
Mt. Washington COOP	17.	21.	37.	33.	27.
New Jersey					
Atlantic City CO	45.	49.	63.	60.	54.
Newark AP	43.	47.	63.	59.	53.
Trenton CO	43.	47.	64.	60.	53.
New Mexico					
Albuquerque AP	46.	50.	67.	63.	57.
Clayton AP	43.	47.	63.	59.	53.
Raton AP	38.	42.	58.	54.	48.
Roswell AP	51.	54.	69.	66.	60.
New York					
Albany AP	36.	40.	59.	54.	47.
Albany CO	38.	43.	61.	56.	49.
Bear Mountain CO	38.	42.	59.	55.	48.
Binghamton AP	34.	38.	56.	52.	45.
Binghamton CO	38.	42.	59.	55.	48.
Buffalo AP	37.	41.	58.	54.	47.
New York AP (La Guardia)	44.	48.	64.	60.	54.
New York CO	44.	47.	63.	59.	53.
New York Central Park	44.	48.	64.	60.	54.
Oswego CO	36.	40.	58.	54.	47.
Rochester AP	37.	41.	58.	54.	47.
Schenectady COOP	35.	40.	59.	55.	47.

Location	Winter	Spring	Summer	Fall	Annual
New York					
Syracuse AP	38.	42.	60.	56.	49.
North Carolina					
Asheville CO	48.	51.	64.	61.	56.
Charlotte AP	52.	55.	69.	66.	60.
Greensboro AP	49.	53.	67.	64.	58.
Hatteras CO	56.	59.	70.	68.	63.
Raleigh AP	51.	55.	69.	65.	60.
Raleigh CO	52.	56.	70.	66.	61.
Wilmington AP	56.	59.	71.	69.	64.
Winston Salem AP	50.	53.	67.	64.	58.
North Dakota					
Bismarck AP	27.	33.	56.	51.	42.
Devils Lake CO	24.	29.	54.	48.	39.
Fargo AP	26.	32.	56.	50.	41.
Minot AP	25.	31.	54.	49.	39.
Williston CO	27.	33.	56.	50.	41.
Ohio					
Akron-Canton AP	39.	43.	60.	56.	50.
Cincinnati AP	43.	47.	64.	60.	54.
Cincinnati CO	46.	50.	66.	63.	56.
Cincinnati ABBE OBS	45.	49.	65.	61.	55.
Cleveland AP	40.	44.	61.	57.	51.
Cleveland CO	41.	45.	62.	58.	51.
Columbus AP	41.	46.	62.	59.	52.
Columbus CO	43.	47.	64.	60.	53.
Dayton AP	42.	46.	63.	59.	52.
Sandusky CO	41.	45.	62.	58.	51.
Toledo AP	38.	43.	60.	56.	49.
Youngstown AP	39.	43.	60.	56.	50.
Oklahoma					
Oklahoma City AP	50.	54.	71.	67.	60.
Oklahoma City CO	50.	55.	71.	68.	61.
Tulsa AP	50.	54.	71.	67.	61.
Oregon					
Astoria AP	47.	48.	56.	54.	51.
Baker CO	36.	40.	56.	52.	46.
Burns CO	36.	40.	58.	54.	47.
Eugene AP	46.	48.	59.	57.	52.
Meacham AP	34.	38.	52.	49.	43.
Medford AP	46.	49.	62.	59.	54.
Pendleton AP	42.	46.	63.	59.	53.
Portland AP	46.	49.	60.	57.	53.
Portland CO	48.	50.	61.	59.	55.

Location	Winter	Spring	Summer	Fall	Annual
Oregon					
Roseburg AP	47.	49.	60.	57.	53.
Roseburg CO	48.	51.	61.	59.	55.
Salem AP	46.	49.	60.	57.	53.
Sexton Summit	42.	44.	55.	52.	48.
Troutdale AP	45.	48.	59.	57.	52.
Pennsylvania					
Allentown AP	40.	44.	62.	58.	51.
Erie AP	38.	42.	58.	55.	48.
Erie CO	40.	44.	60.	56.	50.
Harrisburg AP	43.	47.	63.	59.	53.
Park Place CO	36.	40.	57.	53.	46.
Philadelphia AP	44.	48.	64.	61.	54.
Philadelphia CO	46.	50.	66.	62.	56.
Pittsburgh Allegheny	42.	46.	62.	58.	52.
Pittsburgh GRTR PITT	40.	44.	61.	57.	51.
Pittsburgh CO	44.	48.	64.	60.	54.
Reading CO	43.	47.	64.	60.	54.
Scranton CO	40.	44.	61.	57.	50.
Wilkes Barre-Scranton	39.	43.	60.	56.	49.
Williamsport AP	40.	44.	61.	57.	51.
Rhode Island					
Block Island AP	41.	45.	59.	55.	50.
Providence AP	39.	43.	59.	56.	49.
Providence CO	41.	45.	62.	58.	51.
South Carolina					
Charleston AP	58.	61.	72.	70.	65.
Charleston CO	60.	62.	74.	71.	67.
Columbia AP	56.	59.	72.	69.	64.
Columbia CO	57.	60.	72.	69.	64.
Florence AP	55.	59.	72.	69.	64.
Greenville AP	53.	56.	69.	66.	61.
Spartanburg AP	53.	56.	70.	66.	61.
South Dakota					
Huron AP	31.	37	60.	55.	46.
Rapid City AP	34.	39.	58.	54.	46.
Sioux Falls AP	32.	37.	60.	55.	46.
Tennessee					
Bristol AP	48.	51.	65.	62.	56.
Chattanooga AP	51.	55.	69.	65.	60.
Knoxville AP	50.	54.	68.	65.	59.
Memphis AP	52.	56.	71.	68.	62.
Memphis CO	53.	57.	72.	68.	62.
Nashville AP	51.	54.	69.	66.	60.

Location	Winter	Spring	Summer	Fall	Annual
Tennessee					
Oak Ridge CO	49.	52.	67.	64.	58.
Oak Ridge 8 S	49.	52.	67.	64.	58.
Texas					
Abilene AP	55.	58.	73.	70.	64.
Amarillo AP	47.	50.	67.	63.	57.
Austin AP	60.	63.	76.	73.	68.
Big Springs AP	56.	59.	74.	70.	65.
Brownsville AP	68.	70.	79.	77.	74.
Corpus Christi AP	65.	68.	78.	76.	72.
Dallas AP	57.	61.	76.	72.	66.
Del Rio AP	62.	65.	77.	75.	70.
El Paso AP	54.	58.	72.	69.	63.
Fort Worth AP (Amon Carter)	57.	60.	75.	72.	66.
Galveston AP	63.	66.	77.	74.	70.
Galveston CO	63.	66.	77.	74.	70.
Houston AP	62.	65.	76.	73.	69.
Houston CO	63.	66.	77.	74.	70.
Laredo AP	67.	70.	81.	79.	74.
Lubbock AP	50.	54.	69.	65.	59.
Midland AP	55.	59.	73.	70.	64.
Palestine CO	58.	62.	74.	71.	66.
Port Arthur AP	61.	64.	75.	72.	68.
Port Arthur CO	63.	65.	76.	74.	69.
San Angelo AP	58.	61.	74.	71.	66.
San Antonio AP	61.	64.	77.	74.	69.
Victoria AP	64.	67.	78.	76.	71.
Waco AP	58.	62.	76.	73.	67.
Wichita Falls AP	53.	57.	73.	69.	63.
Utah					
Blanding CO	39.	43.	60.	56.	50.
Milford AP	37.	42.	61.	56.	49.
Salt Lake City AP	40.	44.	63.	59.	51.
Salt Lake City CO	41.	46.	65.	60.	53.
Vermont					
Burlington AP	32.	37.	57.	52.	44.
Virginia					
Cape Henry CO	51.	55.	68.	65.	60.
Lynchburg AP	48.	51.	66.	62.	57.
Norfolk AP	51.	54.	68.	64.	59.
Norfolk CO	52.	56.	69.	66.	61.
Richmond AP	48.	52.	67.	63.	58.
Richmond CO	50.	53.	68.	64.	59.
Roanoke AP	48.	51.	66.	62.	57.

Location	Spring			Fall	Annual
Washington					
Ellensburg AP	37.	41.	59.	55.	48.
Kelso AP	45.	47.	57.	54.	51.
North Head L H RESVN	47.	49.	54.	53.	51.
Olympia AP	44.	46.	56.	54.	50.
Omak 2 mi N W	36.	40.	59.	55.	47.
Port Angeles AP	45.	46.	53.	52.	49.
Seattle AP (Boeing Field)	46.	48.	58.	56.	52.
Seattle CO	47.	50.	59.	57.	53.
Seattle-Tacoma AP	44.	47.	57.	55.	51.
Spokane AP	37.	41.	58.	54.	47.
Stampede Pass	32.	35.	48.	45.	40.
Tacoma CO	46.	48.	58.	55.	52.
Tattosh Island CO	46.	47.	52.	51.	49.
Walla Walla CO	44.	48.	65.	61.	54.
Yakima AP	40.	44.	61.	57.	50.
West Virginia					
Charleston AP	47.	50.	65.	61.	56.
Elkins AP	41.	45.	59.	56.	50.
Huntington CO	48.	52.	67.	63.	57.
Parkersburg CO	45.	49.	65.	61.	55.
Petersburg CO	44.	48.	63.	60.	54.
Wisconsin					
Green Bay AP	31.	36.	56.	51.	44.
La Crosse AP	32.	38.	60.	55.	46.
Madison AP	34.	39.	59.	54.	47.
Madison CO	34.	39.	60.	55.	47.
Milwaukee AP	35.	40.	58.	54.	47.
Milwaukee CO	36.	41.	59.	55.	48.
Wyoming					
Casper AP	34.	38.	57.	52.	45.
Cheyenne AP	35.	39.	55.	51.	45.
Lander AP	31.	35.	56.	51.	43.
Rock Springs AP	31.	35.	54.	50.	42.
Sheridan AP	33.	37.	56.	52.	44.
Hawaii					
Hilo AP	72.	72.	74.	74.	73.
Honolulu AP	74.	75.	77.	77.	76.
Honolulu CO	74.	74.	77.	76.	75.
Lihue AP	72.	73.	76.	75.	74.
Alaska					
Anchorage AP	25.	29.	46.	42.	35.
Annette AP	40.	42.	51.	49.	46.
Barrow AP	4.	7.	16.	14.	10.

Location		Spring	Summer	Fall	Annual
Alaska					
Bethel AP	18.	23.	41.	37.	30.
Cold Bay AP	33.	35.	43.	41.	38.
Cordova AP	32.	35.	45.	43.	39.
Fairbanks AP	14.	19.	38.	34.	26.
Galena AP	13.	18.	37.	33.	25.
Gambell AP	15.	19.	34.	30.	24.
Juneau AP	34.	36.	47.	45.	41.
Juneau CO	36.	39.	49.	46.	42.
King Salmon AP	25.	28.	44.	40.	34.
Kotzebue AP	10.	14.	31.	27.	21.
McGrath AP	14.	18.	37.	33.	25.
Nome AP	16.	20.	37.	33.	26.
Northway AP	12.	16.	32.	29.	22.
Saint Paul Island AP	31.	32.	40.	38.	35.
Yakutat AP	33.	36.	45.	43.	39.
West Indies					
Ponce Santa Isabel AP	75.	76.	78.	78.	77.
San Juan AP	77.	77.	79.	79.	78.
San Juan CO	77.	77.	79.	79.	78.
Swan Island	80.	80.	82.	81.	81.
Virgin Islands					
St. Croix, V.I. AP	78.	78.	81.	80.	79.
Pacific Islands					
Canton Island AP	83.	84.	84.	84.	84.
Koror	81.	81.	81.	81.	81.
Ponape Island AP	81.	81.	81.	81.	81.
Truk Moen Island	81.	81.	81.	81.	81.
Wake Island AP	79.	79.	81.	81.	80.
Yap	81.	81.	82.	82.	82.

Appendix B. Computer Program Listing for Multiple Pipe Heat Transfer and Economic Analysis

The attached computer program calculates pipe heat loss (heat gain) for an underground heat distribution system, for which up to fifteen different pipes are buried. Each of the pipes covered in turn contains up to five inner pipes. All the pipes could be either insulated or uninsulated. The uninsulated pipes are considered to be insulated by material having the same thermal conductivity as that of the surrounding soil. The economic analysis requires the energy cost per million Btu's and capital cost in terms of dollar per linear foot of the installed system. The life-cycle-cost calculation includes the effect of the given discount rate and cost escalation rate. The program allows the determination of minimum life cycle cost with respect to the variation of insulation thickness of one pipe, which may be the subject of major importance.

The following input data will have to be read on the interactive console in response to the questions. The input data will be displayed on the console for validation and correction (if necessary). The sequence of this interactive operation is illustrated at the end of the program listing.

M: number of pipes in the trench
A: horizontal distance of each pipe from a reference pipe, inches
D: depth of each pipe, inches
R: external radius of the pipe (inclusive of insulation and air space if applicable), inches
KS: thermal conductivity of soil, Btu-in/hr.ft².°F
TG: ground temperature, °F
TPF: pipe fluid temperature, °F

For each pipe the layer-by-layer data on

TH: thickness, inches
KI: thermal conductivity, Btu-in/hr.ft².°F

are required in the sequence of carrier pipe wall, insulation, air space, and conduit wall.

The program would output at this point

C: thermal conductance of each pipe, Btu/hr.ft.°F
TP: pipe/soil interface temperature, °F
Q: heat loss/gain from each pipe, Btu/hr, ft
QP: heat loss/gain from each pipe when all the pipes are completely insulated from each other, Btu/hr, ft.

If the cost calculation is required, the following input must be provided:

pipe cost in terms of \$/ft installed
cost of heat in terms of \$/million Btu
total pipe length, ft
annual interest rate, %
price escalation rate, %
the terms of payment in years.

The program would output the percent-worth factor, pipe cost, heat cost and total cost.

If the optimization analysis is required for the insulation thickness for one of the pipes, that particular pipe should be identified. Five steps of insulation thickness, thermal conductivity, and corresponding incremented cost (installed cost) are then inputted to observe the total cost profile, which will in turn provide the optimum insulation thickness.


```

58 COMMON/ACOMT/RJ(15,5),KIJ(15,5),THI(15,5),TPFI(15,5),NP(15)
59 COMMON/BCOMT/R,TH,C1,CH,COSTIN,COSTHT,TOTAL,K1,C,ZL,ZI,ZY,P1,RP
60 REAL C1(15),CH(15)
61 REAL KIJ
62 REAL AC(15),R(15),E(15),FI(5,15),TP(15),TPF(15),Q(15),TH(5,15)
63 REAL KS,PHI(15,15),C(15),CP(15),D(15),PUS(15,15),RES(15)
64 REAL TC(15),AI(15),RI(15),KII(5),THI(5),DI(15),KSI,RP(15)
65 REAL PHIX(15,15)
66 PI=4.*ATAN(1.)
67 CONTINUE
68 PRINT 1111
69 PRINT 1111
70 FORMAT(/////////)
71 PRINT *, ' ENTER H, IN, IFILE'
72 PRINT *, ' H=NO. OF PIPES (MAX 15); IN=1 IF ANY PIPE IS INSULATED'
73 PRINT *, ' IFILE=10 STOP PROGRAM'
74 PRINT *, ' IFILE = FILE NUMBER WHERE DATA ARE TO BE STORED'
75 READ *,H,IN,IFILE
76 IMOD=IFILE
77 PRINT 101,M,IN,IMOD
78 FORMAT(' M='19,5X,' IN='19,5X,' IFILE='13)
79 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
80 READ *,IERR
81 IF(IERR.GE.1) GO TO 19
82 IF(IMOD.EQ.10) GO TO 250
83 IF(IFILE.EQ.0) GO TO 102
84 CALL OPERF(1,'COST2')
85 READ(1)A,R,E, K1,TP,TPF,C,TE,KS,PHI,C,QP,D,PHS,RES,TG,AI,RI,KII
86 *,THI,DI,KSI,RJ,KIJ,THI,TPFI,RP,C1,CH,COSTIN,COSTHT,TOTAL,M,TC
87 GO TO 500
88
89 PRINT *, ' ENTER ARRAY A',M,' VALUES'
90 PRINT *, ' A=HORIZONTAL DISTANCE OF PIPE FROM REFERENCE LINE, IN'
91 READ *,(AI(I),I=1,M)
92 PRINT *, ' A=',(AI(I),I=1,M)
93 FORMAT(' A='7F10.3)
94 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
95 READ *,IERR
96 IF(IERR.GE.1) GO TO 102
97 PRINT *, ' ENTER ARRAY D',M,' VALUES'
98 PRINT *, ' D=DEPTH OF PIPE, INCHES'
99 READ *,(DI(I),I=1,M)
100 PRINT *, ' D=',(DI(I),I=1,M)
101 FORMAT(' D='6F10.3)
102 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
103 READ *,IERR
104 IF(IERR.GE.1) GO TO 104
105 PRINT *, ' ENTER ARRAY R',M,' VALUES'
106 PRINT *, ' R=RADIUS OF PIPE INCLUDING ANY INSULATION, INCHES'
107 READ *,(RI(I),I=1,M)
108 PRINT *, ' R=',(RI(I),I=1,M)
109 FORMAT(' R='6F10.3)
110 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
111 READ *,IERR
112 IF(IERR.GE.1) GO TO 106
113 PRINT *, ' ENTER KS AND TC'
114 PRINT *, ' KS= THERMAL CONDUCTIVITY OF EARTH'
115 PRINT *, ' TC=TEMPERATURE OF GROUND, F'
116 READ *,KSI,TC

```

```

116 PRINT *, ' KS=', KS1, ' TC=', TC, ' T2
117 FORMAT( ' KS='F10.3, 5X, 'TC='F10.3)
118 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
119 READ *, IERR
120 IF (IERR.GE.1) GO TO 103
121 CONTINUE
122 KS=KS1/12.
123 DO 21 L=1,M
124 A(L)=A(L)/12.
125 R(L)=R(L)/12.
126 D(L)=D(L)/12.
127 DO 3 K=1,M
128 DO 3 I=1,M
129 IF (I.EQ.K) GO TO 4
130 EIK=(D(K)+D(I))/R(K)
131 AIK=(A(K)-A(I))/R(K)
132 DIK=(D(K)-D(I))/R(K)
133 PHI(I,K)=ALCG((AIK*AIK+EIK*EIK)/(AIK*AIK+DIK*DIK))/4./PI/KS
134 GO TO 3
135 PHI(K,K)=ALCG(2.*D(K)/R(K))/2./PI/KS
136 RES(K)=PHI(K,K)
137 CONTINUE
138 IF (IN.EQ.0) GO TO 15
139 IF (MOD.NE.0) GO TO 501
140 PRINT *, ' ENTER ARRAY TPF', M, ' VALUES'
141 PRINT *, ' TPF=INTERNAL FLUID TEMPERATURE, F'
142 READ *, (TPF(I), I=1,M)
143 PRINT *, ' TPF=', (TPF(I), I=1,M)
144 FORMAT( ' TPF='6F10.3)
145 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'
146 READ *, IERR
147 IF (IERR.GE.1) GO TO 111
148 PRINT *, ' REPEAT THE FOLLOWING INPUT PROCESS'
149 PRINT *, ' FOR LAYER THICKNESS (INCHES)'
150 PRINT *, ' THERMAL CONDUCTIVITY (BTU-IN/(SQ.FT)(HR)(F))'
151 PRINT *, ' ', M, ' TIMES'
152
C
153 DO 22 I=1,M
154 PRINT *, ' ENTER THICKNESS DATA IN INCHES FOR'
155 PRINT *, ' CARRIER PIPE, 1ST INSULATION, 2ND INSULATION, '
156 PRINT *, ' AIR SPACE, AND CASING FOR PIPE NO. ', I
157 PRINT *, ' YOU MUST ENTER FIVE VALUES SEPARATED'
158 PRINT *, ' BY ' ' IF NOT APPLICABLE, INPUT 0.'
159 READ *, (TH(J,I), J=1,5)
160 PRINT *, ' TH=', (TH(J,I), J=1,5)
161 PRINT *, ' IF ERROR TYPE 1 OTHERWISE TYPE 0'
162 READ *, IERR
163 IF (IERR.GE.1) GO TO 114
164 PRINT *, ' ENTER THERMAL CONDUCTIVITY DATA'
165 PRINT *, ' FOR EACH OF THE LAYERS OF PIPE NO. ', I
166 PRINT *, ' THERMAL CONDUCTANCE OF AIR LAYER KI(4,I) IS'
167 PRINT *, ' ASSUMED 3 BTU/HR.FT**2,F UNLESS'
168 PRINT *, ' YOU HAVE BETTER DATA'
169 READ *, (KI(J,I), J=1,5)
170 PRINT *, ' KI=', (KI(J,I), J=1,5)
171 PRINT *, ' IF ERROR TYPE 1 OTHERWISE TYPE 0'
172 READ *, IERR
173 IF (IERR.GE.1) GO TO 115

```

```

174 TET=0.
175 DO 116 J=1,5
176 TH(J)=TH(J,I)
177 KII(J)=KII(J,I)
178 TH1=TH1+TH(J,I)
179 RP(I)=RI(I)-TET
180 CALL REXR(I),THI,KII,C(I),PI)
181 CONTINUE
182 C
183 6
184
185 PRINT *, ' ENTER ARRAY NP',M,' VALUES'
186 PRINT *, ' NP= NUMBER OF INNER PIPES WITHIN EACH PIPE'
187 READ *,(NP(I),I=1,M)
188 PRINT *, ' NP=',(NP(I),I=1,M), ' IF ERROR TYPE 1, IF NOT TYPE 0'
189 READ *,IERR
190 IF(IERR.GE.1) GO TO 6
191 NPSUR=0
192 DO 221 I=1,M
193 NPSUR=NPSUR+NP(I)
194 IF(NPSUR.NE.0) CALL INPI(C,TPF,M)
195 PRINT *, ' C=THERMAL CONDUCTANCE OF PIPE INSULATION'
196 PRINT I17,(C(K),K=1,M)
197 FORMAT(' C='6F10.3)
198 DO 7 K=1,M
199 B(K)=TC
200 DO 7 I=1,M
201 B(K)=B(K)+C(I)*PHI(I,K)*TPF(I)
202 DO 24 K=1,M
203 DO 8 I=1,M
204 IF(I.EQ.K) GO TO 9
205 PHX(I,K)=C(I)*PHI(I,K)
206 GO TO 8
207 PHX(K,K)=(1.+C(K)*PHI(K,K))
208 CONTINUE
209 DO 125 K=1,M
210 DO 125 I=1,M
211 PHX(I,K)=PHI(I,K)
212 CALL TRANS(PHX,PHI,M)
213 CALL SOLVE(M,M+1,PHI,B,TP,5)
214 PRINT *, ' TP=EXTERNAL SURFACE TEMPERATURE OF PIPE, F'
215 PRINT I18,(TP(I),I=1,M)
216 FORMAT(' TP='6F10.3)
217 DO 10 K=1,M
218 Q(K)=C(K)*(TPF(K)-TP(K))
219 DO 126 K=1,M
220 DO 126 I=1,M
221 PHI(I,K)=PHX(I,K)
222 GO TO 17
223 15
224 IF(IMDD.NE.0) GO TO 502
225 C
226 C
227 THIS SECTION IS APPLICABLE WHEN THE PIPE SURFACE TEMPERATURE
228 IS SPECIFIED OR WHEN IN.EQ.0
229 PRINT *, ' ENTER ARRAY TP',M,' VALUES'
230 PRINT *, ' TP=TEMPERATURE OF PIPE, F'
231 READ *,(TP(I),I=1,M)
232 PRINT I19,(TP(I),I=1,M)
233 FORMAT(' TP='6F10.3)
234 PRINT *, ' IF ERROR TYPE 1; OTHERWISE TYPE 0'

```

```

232 READ *, IERR
233 IF (IERR.GE.1) GO TO 15
234 CONTINUE
235 DO 16 K=1,M
236 TC(K)=TP(K)-TC
237 CALL TRANS(PHI, PHS, M)
238 CALL SOLVP(M, K+1, PES, TC, Q, 5)
239
240 PRINT *, ' Q=HEAT TRANSFER TO AND FROM THE KTH PIPE, BTU/HR, FT'
241 PRINT 120, (Q(I), I=1,M)
242 FORMAT(' Q = '6F10.3)
243 DO 18 K=1,M
244 RESX=0.
245 IF (IN.NE.0) RESX=1./C(K)
246 RES(K)=RES(K)+RESX
247 IF (IN.NE.0) QP(K)=(TP(K)-TC)/RES(K)
248 IF (IN.EQ.0) QP(K)=TC(K)/RES(K)
249 CONTINUE
250 PRINT *, ' QP=PIPE HEAT TRANSFER WHEN THE PIPE IS ISOLATED'
251 PRINT 121, (QP(I), I=1,M)
252 FORMAT(' QP= '6F10.3)
253 PRINT *, ' IF COST CALCULATION IS DESIRED TYPE 1 OTHERWISE'
254 PRINT *, ' TYPE 0'
255 READ *, ICOST
256 IF (ICOST.EQ.0) GO TO 122
257 CALL CCST(Q, I, O)
258 PRINT *, ' IF YOU WISH TO OPTIMIZE INSULATION THICKNESS'
259 PRINT *, ' TYPE 1 OTHERWISE TYPE 0'
260 READ *, INS
261 IF (INS.GE.1) CALL CPT(PHI, TPF, TG, M)
262 GO TO 19
263 IF (MOD(EQ, 10) STOP
264 WRITE(1) A, B, E, K1, TP, TPF, Q, TH, KS, PHI, C, QP, D, PHS, RES, TG, A1, R1, K11
265 *, TH1, DI, KSI, RJ, KIJ, TH11, TPF1, NP, C1, CH, COSTIN, COSTHT, TOTAL, M, TG
266 CALL CLOSE(1, 'CCST2')
267 STOP
268 END

```

```

030303*COSTK(1).TRANS(1)
1  SUBROUTINE TRANS(A,TA,N)
2  C      TRANSPOSE MATRIX FROM A TO TA
3  DIMENSION A(15,15),TA(15,15)
4  DO 1 I=1,N
5  DO 1 J=1,N
6  TA(I,J)=A(J,I)
7  RETURN
8  END

```

```

Q3Q3Q3*COSTK(1).SOLVP(0)
1 SUBROUTINE SOLVP(M,N,C,D,X,I)
2 DIMENSION A(20,20),C(15,15),D(15),X(15)
3 DO 10 IX=1,M
4 DO 10 IY=1,N
5 A(IX,IY)=C(IX,IY)
6 DO 20 IZ=1,N
7 A(IZ,N)=D(IZ)
8 L=1
9 AA=A(L,L)
10 DO 40 K=L,N
11 A(L,K)=A(L,K)/AA
12 DO 60 K=1,N
13 IF (K.EQ.L) GO TO 60
14 AA=-A(K,L)
15 DO 50 IA=L,N
16 A(K,IA)=A(K,IA)+AA*A(L,IA)
17 CONTINUE
18 L=L+1
19 IF(L.LE.M) GO TO 50
20 DO 70 IP=1,N
21 X(IP)=A(IP,N)
22 RETURN
23 END

```

```

QSQSQS**COSTK(1) . INPIPE(5)
1 SUBROUTINE INPIPE(C,TPF,M)
2 COMMON/ACOMM/RI(15,5),KII(15,5),THI(15,5),TPFI(15,5),NP(15)
3 DIMENSION C(15),TPF(15)
4 REAL KII
5 C RI(1,J) RADIUS OF J-TH PIPE INSIDE THE I-TH PIPE INCHES
6 KII(1,J) THERMAL CONDUCTIVITY OF INSULATION AROUND
7 THE J-TH PIPE INSIDE THE I-TH PIPE BTU-IN BASIS
8 THI(1,J) THICKNESS OF THERMAL INSULATION AROUND THE
9 J-TH PIPE INSIDE THE I-TH PIPE....INCHES
10 NP(I) NUMBER OF INNER PIPES INSIDE THE I-TH PIPE
11 TPFI(1,J) FLUID TEMPERATURE OF J-TH PIPE INSIDE
12 THE I-TH PIPE DEGREE F
13 PRINT *, ' ENTER ARRAY TPFI(1,J), RI(1,J), KII(1,J), THI(1,J),
14 PRINT *, ' THESE PARAMETERS REFER TO THE JTH PIPE INSIDE ITH PIPE '
15 PRINT *, ' TPFI=FLUID TEMPERATURE OF THE INNER PIPE F,
16 PRINT *, ' RI= RADIUS OF THE INNER PIPE, INCHES,
17 PRINT *, ' KII= THERMAL CONDUCTIVITY OF INSULATION AROUND '
18 PRINT *, ' THE INNER PIPE BTU-IN/SQ.FT HR F '
19 PRINT *, ' THI=THICKNESS OF INSULATION AROUND THE INNER '
20 PRINT *, ' PIPE INCHES. '
21 CALL INDATA(M)
22 CONTINUE
23 DO 4 I=1,M
24 N=NP(I)
25 SUMRU=0.
26 SUMRUT=0.
27 IF(U.EQ.0) GO TO 4
28 DO 5 J=1,N
29 RU=0.35
30 IF(THI(1,J))6,6,7
31 RI=RI(1,J)+THI(1,J)
32 R2=RI(1,J)
33 XE=ALOG(R1/R2)*RI/KII(1,J)
34 RU=RU+XE
35 U=1./RU
36 SUMRU=SUMRU+RI*U
37 SUMRUT=SUMRUT+RI*U*TPFI(1,J)
38 CONTINUE
39 PU=2.*3.1416*SUMRU
40 PUX=1./C(I)+1./PU
41 C(I)=1./PUX
42 TPF(I)= SUMRUT/SUMRU
43 CONTINUE
44 RETURN
45 END

```

```

1  SUBROUTINE COST(Q,M,INS)
2  DIMENSION R(15),TH(15),CI(15),CH(15),Q(15),C(15),KI(15),RP(15)
3  COMMON/ACOME/R,TH,CI,CH,COSTIN,COSTHT,TOTAL,KI,C,ZL,ZI,ZY,PI,RP
4  COMMON/BCOME/R,TH,CI,CH,COSTIN,COSTHT,TOTAL,KI,C,ZL,ZI,ZY,PI,RP
5  REAL KI,KI1
6  IF(INS.NE.0) GO TO 10
7  PRINT *, ' WE NEED COST OF PIPES AND HEAT GAIN OR LOSS'
8  PRINT *, ' PROVIDE THE COST OF PIPE IN $/FT'
9  PRINT *, ' FOR EACH OF',M,'PIPES'
10 READ *,(CI(I),I=1,M)
11 PRINT *, ' PIPE COST=',(CI(I),I=1,M)
12 PRINT *, ' IF ERROR TYPE 1 OTHERWISE TYPE 0'
13 READ *, IERR
14 IF(IERR.GE.1) GO TO 1
15 PRINT *, ' HEAT COST FOR EACH PIPE IN $ PER MILLION BTUH'
16 READ *,(CH(I),I=1,M)
17 PRINT *, ' COST OF HEAT',(CH(I),I=1,M)
18 PRINT *, ' IF ERROR TYPE 1: OTHERWISE TYPE 0'
19 READ *, IERR
20 IF(IERR.GE.1) GO TO 2
21 PRINT *, ' PROVIDE TOTAL PIPE LENGTH IN FT'
22 READ *, ZL
23 PRINT *, ' PIPE LENGTH=',ZL,'FT'
24 PRINT *, ' IF ERROR TYPE 1 OTHERWISE 0'
25 READ *, IERR
26 IF(IERR.GE.1) GO TO 3
27 PRINT *, ' PROVIDE ANNUAL INTEREST RATE, PRICE ESCALATION RATE IN PERCENT,'
28 PERCENT,
29 PRINT *, ' AND TERM OF PAYMENT IN YEARS RESPECTIVELY'
30 READ *,ZI,ZE,ZY
31 PRINT *, ' INTEREST RATE IS ',ZI,' PERCENT'
32 PRINT *, ' PRICE ESCALATION RATE IS ',ZE,' PERCENT'
33 PRINT *, ' THE TERM OF PAYMENT IS ',ZY,' YEARS'
34 PRINT *, ' IF ERROR TYPE 1 OTHERWISE 0'
35 READ *, IERR
36 IF(IERR.GE.1) GO TO 4
37 COSTIN=0.
38 COSTHT=0.
39 DO 5 I=1,M
40 COSTIN=COSTIN+CI(I)*ZL
41 COSTHT=COSTHT+CH(I)*ABS(Q(I))*ZL*8.760/1000.
42 ZIX=ZI/100.
43 ZEX=ZE/100.
44 Z1=(1.+ZEX)/(ZIX-ZEX)
45 Z2=((1.+ZEX)/(1.+ZIX))*ZY
46 YY=Z1*(1.-Z2)
47 PRINT *, ' PRESENT WORTH FACTOR IS ',YY
48 COSTIN=COSTIN/YY
49 TOTAL=COSTIN+COSTHT
50 PRINT 120,COSTIN
51 PRINT 121,COSTHT
52 PRINT 122,TOTAL
53 FORMAT(' PIPE COST IS $ 'F11.2)
54 FORMAT(' HEAT COST IS $ 'F11.2)
55 FORMAT(' TOTAL COST IS $ 'F10.2)
56 RETURN
57 END

```

```

050305* COSTK(1). INDATA(2)
1 SUBROUTINE INDATA(M)
2 COMMON/ACOM/RI(15,5), KII(15,5), THII(15,5), TPII(15,5), NP(15)
3 REAL KII
4 DO 1 I=1,M
5 PRINT *, ' INPUT FOR OUTER PIPE NO', I
6 N=NP(I)
7 PRINT *, ' NO OF INNER PIPE FOR OUTER PIPE ', I, ' ', N
8 IF(N.EQ.0) GO TO 1
9 DO 2 J=1,N
10 PRINT *, ' DATA FOR INNER PIPE ', J, ' OF OUTER PIPE ', I
11 PRINT 2222, I, J, I, J, I, J
12 FORMAT(' TPII(', I2, ',', I2, '), RI(', I2, ',', I2, '), KII(',
13 * I2, ',', I2, '), THII(', I2, ',', I2, ')')
14 3 READ *, TPII(I, J), RI(I, J), KII(I, J), THII(I, J)
15 PRINT *, TPII(I, J), RI(I, J), KII(I, J), THII(I, J)
16 PRINT *, ' IF ERROR TYPE 1: OTHERWISE TYPE 0'
17 READ *, IERR
18 IF(IERR.GE.1) GO TO 3
19 CONTINUE
20 CONTINUE
21 RETURN
22 END

```

```

05QSQS* COSTK(1).OPT(11)
1 SUBROUTINE OPT(PHI, TPF, TC, MD
2 COMON/ACOMEN/RI(15,5), KI(15,5), TH(15,5), TPFI(15,5), NP(15)
3 COMON/BCOMEN/TH, CI, CCSTIN, COSTHT, TOTAL, KI, C, ZL, ZI, ZY, PI, RP
4 REAL TH(5,15), KI(5,15), R(15), PHI(15,15), TPF(15), TH(5), KIX(5)
5 REAL C(15), C(15), B(15), PES(15,15), TP(15), CI(15), CH(15), RP(15)
6 REAL KII, KIT, ZKIX(10), THKX(10), CISTX(10), PHIX(15,15)
7
8 CONTINUE
9 PRINT *, ' WHICH PIPE INSULATION DO YOU WISH TO OPTIMIZE ?'
10 PRINT *, ' INPUT PIPE NUMBER COUNTING FROM LEFTMOST PIPE '
11 READ *, IP
12 PRINT *, ' INSULATION AROUND PIPE ', IP, ' WILL BE OPTIMIZED'
13 PRINT *, ' IF ERROR TYPE 1 : OTHERWISE TYPE 0'
14 READ *, IERR
15 IF(IERR.GE.1) GO TO 1
16 PRINT *, ' TYPE IN NUMBER OF INSULATION SYSTEMS TO BE STUDIED'
17 PRINT *, ' THE NUMBER CAN BE AS HIGH AS 10 SYSTEMS'
18 READ *, NZ
19 PRINT 10,NZ
20 FORMAT( ' NUMBER OF THE INSULATION SYSTEMS TO BE STUDIED IS' 12)
21 PRINT *, ' IF ERROR TYPE 5 :OTHER WISE TYPE 0'
22 READ *, IERR
23 IF(IERR.GE.1) GO TO 11
24 PRINT 12,NZ
25 FORMAT( ' TYPE' 12, ' VALUES OF THERMAL CONDUCTIVITY FOR INSULATION')
26 READ *, (ZKIX(L), L=1,NZ)
27 PRINT 13,NZ
28 FORMAT( ' TYPE' 12, ' VALUES OF INSULATION THICKNESS')
29 READ *, (THKX(L), L=1,NZ)
30 PRINT 14,NZ
31 FORMAT( ' TYPE' 12, ' VALUES OF INSULATION COST IN $/FT')
32 READ *, (CISTX(L), L=1,NZ)
33 DO 16 L=1,NZ
34 PRINT 17,L,THKX(L),ZKIX(L),CISTX(L)
35 FORMAT( ' SYSTEM NO IS '110/' INSULATION IS'F10.3,' INCH THICK'/
36 *' THERMAL CONDUCTIVITY IS'F10.3,' BTU-IN/SQ.FT,HR, DEG.F'/
37 *' COST OF NEW PIPE IS' F10.2,' $/FT')
38 TH(2,IP)=THKX(L)
39 KI(2,IP)=ZKIX(L)
40 CI(IP)=CISTX(L)
41 THT=0.
42 DO 30 K=1,5
43 THT=THT+THK(K,IP)
44 KIT=0.
45 R(IP)=(RP(IP)+THT)/12.
46 DO 40 J=1,5
47 KIT=KIT+KI(J,IP)
48 TH(J)=TH(J,IP)
49 KIX(J)=KI(J,IP)
50 CALL REX(R(IP),THI,KIX,C(IP),PI)
51 DO 2 K=1,N
52 B(K)= TC
53 DO 2 I=1,N
54 B(K)=B(K)+C(I)*PHI(I,K)*TPF(I)
55 DO 3 K=1,N
56 DO 4 I=1,N
57 IF(1.EQ.K) GO TO 5
58 PES(I,K)=C(I)*PHI(I,K)

```

```

58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82

5      GO TO 4
6      CONTINUE
7      PHS(K,KO)=(1.+C(KO)*PHI(K,KO))
8      CONTINUE
9      CONTINUE
10     DO 20 K=1,M
11     DO 20 I=1,N
12     PHIX(I,K)=PHI(I,K)
13     CALL TRANS(PHS,PHI,M)
14     CALL SOLVP(N,M+1,PHI,B,TP,5)
15     DO 6 K=1,N
16     Q(KO)=C(KO)*(TP(K)-TP(KO))
17     PRINT 121,(Q(I),I=1,N)
18     FORMAT( , NEW Q = , 6F10.3)
19     DO 19 K=1,M
20     DO 19 I=1,N
21     PHIX(I,K)=PHIX(I,K)
22     CALL CCST(Q,M,1)
23     CONTINUE
24     PRINT *, ' DO YOU WISH TO CONTINUE WITH DIFFERENT INSULATION?'
25     PRINT *, ' IF YES TYPE 1: OTHERWISE TYPE 0'
26     READ *, ICONT
27     IF (ICONT.EQ.0) RETURN
28     GO TO 8
29     END

```

```

05050505**COSTK(1).REX(8)
1 SUBROUTINE REX(R,TH,KI,C,PI)
2 REAL TH(5),KI(5)
3 THT=0.
4 DO 1 K=1,5
5 1 THT=THT+TH(K)
6 R1=R*12.-THT
7 R2=R1+TH(1)
8 R3=R2+TH(2)
9 R4=R3+TH(3)
10 R5=R4+TH(4)
11 R6=R5+TH(5)
12 PRINT *, ' THT= ', THT, ' R= ', R, ' PI= ', PI
13 PRINT *, ' R1 THTU R6= ', R1, R2, R3, R4, R5, R6
14 X1=0.
15 IF(R2.GT.R1) X1=ALOG(R2/R1)*12./KI(1)
16 X2=0.
17 IF(R3.GT.R2) X2=ALOG(R3/R2)*12./KI(2)
18 X3=0.
19 IF(R4.GT.R3) X3=ALOG(R4/R3)*12./KI(3)
20 X4=0.
21 IF(R5.GT.R4) X4=1./R4/KI(4)
22 X5=0.
23 IF(R6.GT.R5) X5=ALOG(R6/R5)*12./KI(5)
24 X=X1+X2+X3+X4+X5
25 C=1./X**2.*PI
26 RETURN
27 END

```

```

QSQSQSQ*COSTK(1).DATA(2)
1 3,1,0
2 0
3 0.,45.,80.
4 0
5 43.,43.,43.
6 0
7 20.,20.,10.
8 0
9 10.,60.
10 0
11 45.,50.,210.
12 0
13 0.25,4.,0.,0.,0.125
14 0
15 300.,0.66,0.,0.,300.
16 0
17 0.25,4.,0.,0.,0.125
18 0
19 300.,.66,0.,0.,300.
20 0
21 0.25,4.,0.,0.,0.125
22 0
23 300.,.66,0.,0.,300.
24 0
25 0,0,0
26 0
27 1
28 50.,50.,30.
29 0
30 2.,2.,1.
31 0
32 2000.
33 0
34 12.,10.,20.
35 0
36 1
37 2
38 0
39 5
40 0
41 .66,.66,.66,.66,.66
42 1.,2.,3.,4.,5.
43 10.,20.,30.,40.,50.
44 0
45 0,0,10
46 0
END PRT
@XQT

```

ENTER M, IN, IF FILE
 N=NO. OF PIPES (MAX 15); IN=1 IF ANY PIPE IS INSULATED
 IF FILE=10 STOP PROGRAM
 IF FILE = FILE NUMBER WHERE DATA ARE TO BE STORED

```

@ADD, P COSTK. DATA
M= 3      IN= 1      IF FILE= 0
IF ERROR TYPE 1; OTHERWISE TYPE 0
ENTER ARRAY A      3 VALUES
A=HORIZONTAL DISTANCE OF PIPE FROM REFERENCE LINE, IN
A= .00000000      45.000000      80.000000
IF ERROR TYPE 1; OTHERWISE TYPE 0
ENTER ARRAY D      3 VALUES
D=DEPTH OF PIPE, INCHES
D= 43.000000      43.000000      43.000000
IF ERROR TYPE 1; OTHERWISE TYPE 0
ENTER ARRAY R      3 VALUES
R=RADIUS OF PIPE INCLUDING ANY INSULATION, INCHES
R= 20.000000      20.000000      10.000000
IF ERROR TYPE 1; OTHERWISE TYPE 0
ENTER KS AND TC
KS=THERMAL CONDUCTIVITY OF EARTH
TC=TEMPERATURE OF GROUND, F
KS= 10.000000      TC= 60.000000
IF ERROR TYPE 1; OTHERWISE TYPE 0
ENTER ARRAY TPF      3 VALUES
TPF=INTERNAL FLUID TEMPERATURE, F
TPF= 45.000000      50.000000      210.000000
IF ERROR TYPE 1; OTHERWISE TYPE 0
REPEAT THE FOLLOWING INPUT PROCESS
FOR LAYER THICKNESS (INCHES)
THERMAL CONDUCTIVITY (BTU-IN/(SQ.FT)(HR)(F))
3 TIMES
ENTER THICKNESS DATA IN INCHES FOR
CARRIER PIPE, 1ST INSULATION, 2ND INSULATION,
AIR SPACE, AND CASING FOR PIPE NO.      1
YOU MUST ENTER FIVE VALUES SEPARATED
BY , . IF NOT APPLICABLE, INPUT 0.      .000000000      .000000000      .125000000
TH= .250000000      4.00000000      .000000000
IF ERROR TYPE 1 OTHERWISE TYPE 0
ENTER THERMAL CONDUCTIVITY DATA
FOR EACH OF THE LAYERS OF PIPE NO.      1
THERMAL CONDUCTANCE OF AIR LAYER KI(4,1) IS
ASSUMED 3 BTU/HR.FT**2.F UNLESS
YOU HAVE BETTER DATA
KI= 300.00000      .660000000      .000000000      300.000000
IF ERROR TYPE 1 OTHERWISE TYPE 0
THI= 4.3750000      R= 1.6666667      PI= 3.1415927
R1 THRU R6= 15.625000      15.875000      19.875000      19.875000      20.000000
ENTER THICKNESS DATA IN INCHES FOR
CARRIER PIPE, 1ST INSULATION, 2ND INSULATION,
AIR SPACE, AND CASING FOR PIPE NO.      2
YOU MUST ENTER FIVE VALUES SEPARATED
BY , . IF NOT APPLICABLE, INPUT 0.

```

TH= .25000000 4.00000000 .00000000 .00000000 .12500000
 IF ERROR TYPE 1 OTHERWISE TYPE 0
 ENTER THERMAL CONDUCTIVITY DATA
 FOR EACH OF THE LAYERS OF PIPE NO. 2
 THERMAL CONDUCTANCE OF AIR LAYER KI(4,1) IS
 ASSUMED 3 BTU/HR,FT**2,F UNLESS
 YOU HAVE BETTER DATA
 KI= 300.00000 .66000000 .00000000 .00000000 300.00000
 IF ERROR TYPE 1 OTHERWISE TYPE 0
 TH= 4.3750000 R= 1.6666667 PI= 3.1415927
 R1 THRU R6= 15.625000 15.875000 19.875000 19.875000 20.000000
 ENTER THICKNESS DATA IN INCHES FOR
 CARRIER PIPE, 1ST INSULATION, 2ND INSULATION, 3
 AIR SPACE, AND CASING FOR PIPE NO.
 YOU MUST ENTER FIVE VALUES SEPARATED
 BY ' ' IF NOT APPLICABLE, INPUT 0.
 TH= .25000000 4.00000000 .00000000 .00000000 .12500000
 IF ERROR TYPE 1 OTHERWISE TYPE 0
 ENTER THERMAL CONDUCTIVITY DATA
 FOR EACH OF THE LAYERS OF PIPE NO. 3
 THERMAL CONDUCTANCE OF AIR LAYER KI(4,1) IS
 ASSUMED 3 BTU/HR,FT**2,F UNLESS
 YOU HAVE BETTER DATA
 KI= 300.00000 .66000000 .00000000 .00000000 300.00000
 IF ERROR TYPE 1 OTHERWISE TYPE 0
 TH= 4.3750000 R= .83333333 PI= 3.1415927
 R1 THRU R6= 5.6249999 5.8749999 9.8749999 9.8749999 9.9999999
 ENTER ARRAY NP
 NP= NUMBER OF INNER PIPES WITHIN EACH PIPE
 NP= 0
 C-THERMAL CONDUCTANCE OF PIPE INSULATION 0 IF ERROR TYPE 1, IF NOT TYPE 0
 C= 1.537 1.537 .665
 TP-EXTERNAL SURFACE TEMPERATURE OF PIPE, F
 TP= 57.203 65.697 87.594
 Q=HEAT TRANSFER TO AND FROM THE KTH PIPE,BTU/HR,FT
 Q = -18.763 -24.134 81.437
 QP-PIPE HEAT TRANSFER WHEN THE PIPE IS ISOLATED
 QP= -16.147 -10.764 78.369
 IF COST CALCULATION IS DESIRED TYPE 1 OTHERWISE
 TYPE 0
 WE NEED COST OF PIPES AND HEAT GAIN OR LOSS
 PROVIDE THE COST OF PIPE IN \$/FT
 FOR EACH OF 3PIPES
 PIPE COST= 50.000000 50.000000 30.000000
 IF ERROR TYPE 1 OTHERWISE TYPE 0
 HEAT COST FOR EACH PIPE IN \$ PER MILLION BTUH
 COST OF HEAT 2.0000000 2.0000000 1.0000000
 IF ERROR TYPE 1: OTHERWISE TYPE 0
 PROVIDE TOTAL PIPE LENGTH IN FT
 PIPE LENGTH= 2000.0000 FT
 IF ERROR TYPE 1 OTHERWISE 0
 PROVIDE ANNUAL INTEREST RATE, PRICE ESCALATION RATE IN PERCENT,
 AND TERM OF PAYMENT IN YEARS, RESPECTIVELY
 INTEREST RATE IS 12.000000 PERCENT
 PRICE ESCALATION RATE IS 10.000000 PERCENT
 THE TERM OF PAYMENT IS 20.000000 YEARS
 IF ERROR TYPE 1 OTHERWISE 0
 PRESENT WORTH FACTOR IS 16.642001

PIPE COST IS \$ 15623.12
HEAT COST IS \$ 2929.86
TOTAL COST IS \$ 18552.98

IF YOU WISH TO OPTIMIZE INSULATION THICKNESS

TYPE 1 OTHERWISE TYPE 0

WHICH PIPE INSULATION DO YOU WISH TO OPTIMIZE ?

INPUT PIPE NUMBER COUNTING FROM LEFTMOST PIPE

INSULATION AROUND PIPE 2 WILL BE OPTIMIZED

IF ERROR TYPE 1 : OTHERWISE TYPE 0

TYPE IN NUMBER OF INSULATION SYSTEMS TO BE STUDIED

THE NUMBER CAN BE AS HIGH AS 10 SYSTEMS

NUMBER OF THE INSULATION SYSTEMS TO BE STUDIED IS 5

IF ERROR TYPE 5 : OTHERWISE TYPE 0

TYPE 5 VALUES OF THERMAL CONDUCTIVITY FOR INSULATION

TYPE 5 VALUES OF INSULATION THICKNESS

TYPE 5 VALUES OF INSULATION COST IN \$/FT

SYSTEM NO IS

INSULATION IS 1.000 INCH THICK

THERMAL CONDUCTIVITY IS .660 BTU-IN/SQ.FT.HR, DEG.F

COST OF NEW PIPE IS 10.00 \$/FT

THT= 1.3750000 R= 1.4166667 PI= 3.1415927

R1 THRU R6= 15.625000 15.875000 16.875000

NEW Q = -14.623 -51.593 83.951

PRESENT WORTH FACTOR IS 16.642001

PIPE COST IS \$ 15623.12

HEAT COST IS \$ 3790.69

TOTAL COST IS \$ 19413.81

SYSTEM NO IS

INSULATION IS 2.000 INCH THICK

THERMAL CONDUCTIVITY IS .660 BTU-IN/SQ.FT.HR, DEG.F

COST OF NEW PIPE IS 20.00 \$/FT

THT= 2.3750000 R= 1.5000000 PI= 3.1415927

R1 THRU R6= 15.625000 15.875000 17.875000

NEW Q = -16.846 -36.841 82.601

PRESENT WORTH FACTOR IS 16.642001

PIPE COST IS \$ 15623.12

HEAT COST IS \$ 3328.36

TOTAL COST IS \$ 18951.48

SYSTEM NO IS

INSULATION IS 3.000 INCH THICK

THERMAL CONDUCTIVITY IS .660 BTU-IN/SQ.FT.HR, DEG.F

COST OF NEW PIPE IS 30.00 \$/FT

THT= 3.3750000 R= 1.5933333 PI= 3.1415927

R1 THRU R6= 15.625000 15.875000 18.875000

NEW Q = -18.028 -29.003 81.883

PRESENT WORTH FACTOR IS 16.642001

PIPE COST IS \$ 15623.12

HEAT COST IS \$ 3082.56

TOTAL COST IS \$ 18705.69

SYSTEM NO IS

INSULATION IS 4.000 INCH THICK

THERMAL CONDUCTIVITY IS .660 BTU-IN/SQ.FT.HR, DEG.F

COST OF NEW PIPE IS 40.00 \$/FT

THT= 4.3750000 R= 1.6666667 PI= 3.1415927

R1 THRU R6= 15.625000 15.875000 19.875000

NEW Q = -18.763 -24.134 81.437

PRESENT WORTH FACTOR IS 16.642001

PIPE COST IS \$ 15623.12

17.0000000

16.875000

16.875000

18.0000000

17.875000

17.875000

19.0000000

18.875000

18.875000

20.0000000

19.875000

19.875000

```

HEAT COST IS C      2929.86
TOTAL COST IS C     18552.98
SYSTEM NO IS      5
INSULATION IS      5.000 INCH THICK
THERMAL CONDUCTIVITY IS .660 BTU-IN/SG.FT, HR, DEG.F
COST OF NEW PIPE IS  50.00 $/FT
THT= 5.3750000    R=  1.7500000    PI=  3.1415927
RI THRU R6= 15.625000  15.875000  20.875000
NEW Q = -19.264 -20.811  81.133
PRESENT NORTH FACTOR IS  16.642001
PIPE COST IS C     15623.12
HEAT COST IS C     2835.67
TOTAL COST IS C     18448.79
DO YOU WISH TO CONTINUE WITH DIFFERENT INSULATION?
IF YES TYPE 1; OTHERWISE TYPE 0

```

```

20.875000      20.875000      21.000000

```

```

ENTER M, IN, IFILE
M=NO. OF PIPES (MAX 15); IN=1 IF ANY PIPE IS INSULATED
IFILE=10 STOP PROGRAM
IFILE = FILE NUMBER WHERE DATA ARE TO BE STORED
M= 0    IN= 0    IFILE= 10
IF ERROR TYPE 1; OTHERWISE TYPE 0

```

```

@PRT,S COSTK.MAIN,.TRANS,.SOLVP,.INPIPE,.COST,.INDATA,.OPT,.REX,.DATA
PUPP0R 26R1 U1 E35 S74T11 03/10/81 15:15:55

```

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET <i>(See instructions)</i>	1. PUBLICATION OR REPORT NO. NBSIR 81 2378	2. Performing Organ. Report No.	3. Publication Date November 1981
4. TITLE AND SUBTITLE HEAT TRANSFER ANALYSIS OF UNDERGROUND HEAT AND CHILLED-WATER DISTRIBUTION SYSTEMS			
5. AUTHOR(S) T. Kusuda			
6. PERFORMING ORGANIZATION (If joint or other than NBS, see instructions) NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234			7. Contract/Grant No. 8. Type of Report & Period Covered
9. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Tri-Services: Naval Facilities Engrg. Council, USN, Washington, DC 20390 Directorate of Civil Engrg., USAF, Washington, DC 20330 Office of Chief of Engrs., U.S.Army, Washington, DC 20304			
10. SUPPLEMENTARY NOTES ☐ Document describes a computer program; SF-185, FIPS Software Summary, is attached.			
11. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here) Simplified calculation procedures for determining heat exchange between the earth and a multiplicity of buried pipes having different temperature and thermal insulation are presented. The procedures deal with cases where pipes are buried side by side, as well as those when several pipes are bundled in a conduit. The effects of seasonal variation of earth temperature are treated in a quasi-steady-state equation that includes the soil thermal properties, depth of burial, pipe sizes, and relative locations of pipes. Sample calculations are included, together with the Fortran program listing and thermal properties of earth to be used for the calculations.			
12. KEY WORDS (Six to twelve entries; alphabetical order; capitalize only proper names; and separate key words by semicolons) computer program; earth temperature; heat transfer; pipes; thermal insulation; thermal properties; underground systems.			
13. AVAILABILITY ☒ Unlimited ☐ For Official Distribution. Do Not Release to NTIS ☐ Order From Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. ☒ Order From National Technical Information Service (NTIS), Springfield, VA. 22161			14. NO. OF PRINTED PAGES 62 15. Price \$8.00

